

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Atlantic Construction

Address: 307 Rainmaker St

Date: 12-30-16

Permit Numbers

Building: _____

Electrical: 16-5023911

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Building Official: James Z Hall

ADDRESS : 307 RAINMAKER ST SUBDIV: SWEETWATER 71LOTS
 CONTRACTOR : ATLANTIC CONSTRUCTION PHONE : (910) 938-9053
 OWNER : DIVERSIFIELD INVESTORS INC PHONE :
 PARCEL : 01-0544- - -0004- -43-
 APPL NUMBER: 16-50039111 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/05/2016 12:44 PM LBENNETT --
 SOUTH 401 TURN RIGHT ONTO W REEVES
 BRIDGE RD - LEFT ONTO WILL LUCAS RD -
 LEFT ONTO HYBRID LN - RIGHT ONTO
 RAINMAKER ST

STRUCTURE: 000 000 40X40 4BDR W/GARAGE SLAB FINISH BONUS

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/30/16	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002864056
	8/30/16	AP	NO T-POLE
A814 01	9/07/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002867281
	9/07/16	AP	307 RAINMAKER ST LINDEN 28356 T/S: 09/07/2016 09:30 AM SBENNETT
B103 01	9/07/16	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002867273
	9/07/16	AP	T/S: 09/06/2016 01:10 PM JBROCK T/S: 09/07/2016 02:42 PM MREARIC
P309 01	9/12/16	JH	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002869907
	9/12/16	CA	PER JOHN
P309 02	9/13/16	JH	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002870467
	9/13/16	AP	T/S: 09/12/2016 01:30 PM JBROCK
B111 01	9/16/16	JH	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002872521
	9/16/16	DA	T/S: 09/15/2016 01:41 PM JBROCK 1)Missing lug footing at end of garage wall per plans.2)Missing 6 mill poly on garage slab.
B111 02	9/19/16	JH	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002873073
	9/19/16	AP	T/S: 09/16/2016 01:34 PM JBROCK
B104 01	9/29/16	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002878932
	9/29/16	AP	T/S: 09/29/2016 08:00 AM JBROCK
R425 01	11/01/16	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002891885
	11/01/16	CA	T/S: 10/31/2016 08:40 AM JBROCK T/S: 11/01/2016 01:13 PM MREARIC
R425 02	11/03/16	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002893501
	11/03/16	AP	T/S: 11/02/2016 11:50 AM JBROCK T/S: 11/03/2016 01:35 PM MREARIC
I129 01	11/08/16	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002895118
	11/08/16	AP	T/S: 11/07/2016 08:26 AM JBROCK
H824 01	12/05/16	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002907483
	12/05/16	AP	T/S: 12/06/2016 10:52 AM KHINSON T/S: 12/06/2016 10:52 AM KHINSON
E209 01	12/13/16	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002909687
	12/13/16	CA	T/S: 12/12/2016 09:57 AM DJOHNSON

PREPARED 12/29/16, 14:38:08
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 10
DATE 12/30/16

ADDRESS : 307 RAINMAKER ST
CONTRACTOR : ATLANTIC CONSTRUCTION
OWNER : DIVERSIFIELD INVESTORS INC
PARCEL : 01-0544- - -0004- -43-
APPL NUMBER: 16-50039111 CP NEW RESIDENTIAL (SFD)

SUBDIV: SWEETWATER 71LOTS
PHONE : (910) 938-9053
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E209 02	12/15/16 12/15/16	JH AP	PER JOHN R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002910750 T/S: 12/14/2016 10:26 AM JBROCK
R429 01	12/28/16 12/28/16	JH CA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002914174 T/S: 12/22/2016 11:49 AM JBROCK
R429 02	12/30/16 <i>12-30-16</i>	TI <i>APJ</i>	PER JOHN FOUR TRADE FINAL TIME: 17:00 VRU #: 002915536 T/S: 12/29/2016 02:14 PM LBENNETT

----- COMMENTS AND NOTES -----