

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 43027 Design Flow (.1949): 480 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2	0-12	GS	VFL NS/VR					
		12-36	SBKC	F1 SS/SP					
		36-40	SBKCL	FL SS/S					P1.5
		40-72	GS	VFL NS/VR					
2		0-16	GS	VFL NS/VR					
		16-36	SBKC	FL SS/SP					P1.5
		36-70	GS	VFL NS/VR					
3		0-24	GS	VFL NS/VR					
		24-50	SBKC	FL SS/SP					P3.2
		50-72	GS	VFL NS/VR					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>P1</u> Evaluated By: <u>JK</u> Others Present: <u>-</u>
Available Space (.1945)	<u>✓</u>	<u>✓</u>	
System Type(s)	<u>2S-2</u>	<u>VRSD</u>	
Site LTAR	<u>1.5</u>	<u>1.2</u>	