

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: ROYAL OAKS BLDG. GRP. PROPERTY LOCATION: CAROLINA CT. SUBDIVISION: ATKINS VILLAGE LOT # 28. Type of Structure: SFD (45'x67'). Proposed Wastewater System Type: 25% REDUCTION SYSTEM. Projected Daily Flow: 480 GPD. Number of bedrooms: 4. Number of Occupants: 8 max. Type of Water Supply: Public. Permit valid for: Five years.

Authorized State Agent: [Signature] Date: 8/29/16 SEE ATTACHED SITE SKETCH. The issuance of this permit by the Health Department in no way guarantees the issuance of other permits.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: ROYAL OAKS BLD. GRP. PROPERTY LOCATION: CAROLINA CT. SUBDIVISION: ATKINS VILLAGE LOT # 28. Facility Type: SFD (45'x67'). Type of Wastewater System: 25% REDUCTION SYSTEM. (Initial) Wastewater Flow: 480 GPD. Installation Requirements/Conditions: Number of trenches: 1. Exact length of each trench: 210 feet. Trench Spacing: 9 Feet on Center. Soil Cover: 12 inches.

Installation Requirements/Conditions: Septic Tank Size 1000 gallons. Pump Tank Size [blank] gallons. Trenches shall be installed on contour at a Maximum Trench Depth of: 24 inches. Pump Requirements: [blank] ft. TDH vs. [blank] GPM. Conditions: PERMIT BASED ON PROPOSAL FROM APPLICANTS LSS.

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: [Signature] Date: [blank]

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 8/29/16 Construction Authorization Expiration Date: 8/29/16