Department of Environment, Health and Natural Sources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

## SOIL/SITE EVALUATION
## for ON-SITE WASTEWATER SYSTEM

Owner:                    Applicant:
Address:                              Date Evaluated:
Proposed Facility:  4 BDRM    Design Flow (.1949): 480g    Property Size:
Location of Site:                  Property Recorded:
Water Supply:        ☒ Public ☐ Individual    ☐ Well    ☐ Spring    ☐ Other
Evaluation Method: ☒ Auger Boring    ☐ Pit    ☐ Cut
Type of Wastewater: ☒ Sewage    ☐ Industrial Process    ☐ Mixed

| P R O F I L E # | .1940 Landscape Position/ Slope % | Horizon Depth (In.) | SOIL MORPHOLOGY .1941 | | OTHER PROFILE FACTORS | | | | Profile Class & LTAR |
| | | | .1941 Structure/ Texture | .1941 Consistence Mineralogy | .1942 Soil Wetness/ Color | .1943 Soil Depth (IN.) | .1956 Sapro Class | .1944 Restr Horiz | |
|---|---|---|---|---|---|---|---|---|---|
| 1 | FS 2-5 | 0-24 | Vfm SL | | | | | | |
| | | 24-40 | Yr SCL | | @38" | | | | |
| | | | | | | | | | |
| 2 | | 0-28 | VfR SL | | | | | | |
| | | 28-40 | FD SCL | | | | | | |
| | | | BT @ 40" | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

| Description | Initial System | Repair System | Other Factors (.1946): |
|---|---|---|---|
| | | | Site Classification (.1948): |
| Available Space (.1945) | | | Evaluated By: |
| System Type(s) | | | Others Present: |
| Site LTAR | | | |

COMMENTS: _____

| LANDSCAPE POSITIONS | GROUP | TEXTURES | .1955 LTAR | CONSISTENCE MOIST | WET |
|---|---|---|---|---|---|
| R-RIDGE | I | S-SAND | 1.2 - 0.8 | | |
| S-SHOULDER SLOPE | | LS-LOAMY SAND | | VFR-VERY FRIABLE | NS-NON-STICKY |
| L-LINEAR SLOPE | | | | FR-FRIABLE | SS-SLIGHTY STICKY |
| FS-FOOT SLOPE | II | SL-SANDY LOAM | 0.8 - 0.6 | FI-FIRM | S-STICKY |
| N-NOSE SLOPE | | L-LOAM | | VFI-VERY FIRM | VS-VERY STICKY |
| H-HEAD SLOPE | | | | EFI-EXTREMELY FIRM | NP-NON-PLASTIC |
| CC-CONCLAVE SLOPE | III | SI-SILT | 0.6 - 0.3 | | SP-SLIGHTLY STICKY |
| CV-CONVEX SLOPE | | SIL-SILT LOAM | | | P-PLASTIC |
| T-TERRACE | | CL-CLAY LOAM | | | VP-VERY PLASTIC |
| FP-FLOOD PLAN | | SCL-SANDY CLAY LOAM | | | |
| | IV | SIC-SILTY CLAY | 0.4 - 0.1 | | |
| | | C-CLAY | | | |
| | | SC-SANDY CLAY | | | |

**STRUCTURE**
SG-SINGLE GRAIN
M- MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY
PR-PRISMATIC

**MINERALOGY**
SLIGHTLY EXPANSIVE

EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)