

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: RONALD DAWES
NEW [X] REPAIR [] EXPANSION []
PROPERTY LOCATION: Hwy 55
SUBDIVISION: Pointers Creek LOT # 6
Type of Structure: SFD
Proposed Wastewater System Type: 25" Reducer
Projected Daily Flow: 480 GPD
Number of bedrooms: 4 Number of Occupants: 8 max
Basement [] Yes [X] No
Pump Required: [X] Yes [] No
Type of Water Supply: [] Community [] Public [X] Well
Distance from well 100' feet
Permit valid for: [X] Five years [] No expiration

Authorized State Agent: James E. Manhart Date: 2-22-17 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: RONALD DAWES
PROPERTY LOCATION: Hwy 55
SUBDIVISION: Pointers Creek LOT # 6
Facility Type: SFD [X] New [] Expansion [] Repair []
Basement? [] Yes [X] No Basement Fixtures? [] Yes [X] No
Type of Wastewater System: 25" Reducer System (Initial) Wastewater Flow: 480 GPD
(See note below, if applicable [])
25" Reducer (Repair)
Installation Requirements/Conditions
Septic Tank Size 1200 gallons Exact length of each trench 75 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1200 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 20-718 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Soil Cover: 6 inches
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe, 2 inches above pipe, 12 inches total
Conditions: _____

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Manhart Date: 2-22-17
Construction Authorization Expiration Date: 2-22-22

HTE# 16-5-39310R

Permit # 29178

Harnett County Department of Public Health Site Sketch

ISSUED TO: Ronald Dawes PROPERTY LOCATOR: Hwy 55
SUBDIVISION: Pointers Creek LOT # 6
Authorized State Agent: James E. Markham Date: 2-22-12

