

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: S7D

Permit Numbers

Name: Wynn Construction Inc.

Building: _____

Address: 66 Rowland Dr.

Electrical: 50039345

700way Varina 27526

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Date: 6/6/2017

Building Official: _____

[Signature]

ADDRESS . : 66 ROWLAND DR SUBDIV: AVERY POND 32LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . : WYNN CONSTRUCTION INC PHONE :
 PARCEL . . : 08-0653- - -0029- -10-
 APPL NUMBER: 16-50039345 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/01/2016 08:39 AM DJOHNSON --
 AVERY POND LOT 10

STRUCTURE: 000 000 53X64 4 BR ATT GARAGE DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : EXISTING WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	2/07/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002929982
	2/07/17	AP	66 ROWLAND DR FUQUAY VARINA 27526 T/S: 02/07/2017 09:40 AM SBENNETT -----
B101 01	2/07/17	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002929990
	2/07/17	AP	T/S: 02/06/2017 01:06 PM JBROCK ----- T/S: February 07, 2017 09:10 AM BSUTTON -----
B101 02	2/14/17	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002932598
	2/14/17	AP	T/S: 02/13/2017 09:46 AM LBENNETT ----- REINSPECT PIER FOOTINGS T/S: February 14, 2017 11:30 AM BSUTTON -----
B103 01	2/20/17	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002935161
	2/20/17	AP	T/S: 02/17/2017 02:51 PM LBENNETT ----- T/S: February 20, 2017 09:40 AM BSUTTON -----
B105 01	2/28/17	DT	R*OPEN FLOOR TIME: 17:00 VRU #: 002938546
	2/28/17	AP	T/S: 02/27/2017 12:56 PM DJOHNSON ----- T/S: 02/28/2017 03:45 PM DETAYLOR -----
R425 01	3/22/17	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002947638
	3/22/17	DA	T/S: 03/21/2017 11:38 AM BPETRICH ----- T/S: March 22, 2017 12:11 PM BSUTTON ----- 1. Strap top plates at garage wall/house. 2. Need air barriers under stairs. 3. Improper uplift at girder trusses. 4. Need receptacle each side of garage with no other receptacles on that circuit. 5. Flash front porch. OK to side/insulate
I129 01	3/28/17	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002950319
	3/28/17	AP	T/S: 03/27/2017 12:23 PM LBENNETT ----- T/S: March 28, 2017 09:42 AM BSUTTON -----
R425 02	3/28/17	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002950327
	3/28/17	AP	T/S: 03/27/2017 12:23 PM LBENNETT ----- T/S: March 28, 2017 09:42 AM BSUTTON -----
R125 01	4/06/17	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002955318
	4/06/17	AP	T/S: 04/05/2017 01:35 PM JBROCK ----- STONE INSPECTION T/S: April 06, 2017 11:24 AM BSUTTON -----
E209 01	5/05/17	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002968584
	5/05/17	AP	T/S: 05/04/2017 01:13 PM BPETRICH ----- T/S: May 05, 2017 01:26 PM BSUTTON -----
M305 01	5/09/17	BS	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 002969848
	5/09/17	AP	T/S: 05/08/2017 01:44 PM LBENNETT -----

ADDRESS : 66 ROWLAND DR
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER : WYNN CONSTRUCTION INC
 PARCEL : 08-0653- - -0029- -10-
 APPL NUMBER: 16-50039345 CP NEW RESIDENTIAL (SFD)

SUBDIV: AVERY POND 32LOTS
 PHONE : (919) 528-1347
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	5/17/17 5/17/17	JM AP	T/S: May 09, 2017 10:40 AM BSUTTON ----- ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002974681 T/S: 05/18/2017 11:04 AM KHINSON ----- T/S: 05/18/2017 11:04 AM KHINSON -----
R429 01	5/26/17 5/26/17	BS DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002977403 T/S: 05/25/2017 02:02 PM BPETRICH ----- T/S: May 26, 2017 11:08 AM BSUTTON ----- 1. Cant support deck on cantilever. 2. insulate cantilever and close off. 3. Flashing at deck band must be out and over siding below. 4. Insulation hanging under house.
R429 02	6/06/17 <u>AP</u>	TI <u>P</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002980746 T/S: 06/05/2017 01:29 PM JBROCK -----

----- COMMENTS AND NOTES -----