

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 BORM Design Flow (.1949): 360 gal Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

| P R O F I L E # | .1940 Landscape Position/ Slope % | Horizon Depth (In.) | SOIL MORPHOLOGY .1941 | | OTHER PROFILE FACTORS | | | | Profile Class & LTAR |
|--------------------------------------|--|---------------------------|--------------------------------|------------------------------------|------------------------------------|------------------------------|-------------------------|-------------------------|----------------------------|
| | | | .1941 Structure/ Texture | .1941 Consistence Mineralogy | .1942 Soil Wetness/ Color | .1943 Soil Depth (IN.) | .1956 Sapro Class | .1944 Restr Horiz | |
| 1 | L3 2-5 | 0-28 | G LS | VF2ND/HP | | | | | |
| | | 28-40 | SBKSL | F0.50/SP | | | | | P5 .4 |
| 2 | | 0-22 | G LL | VF2ND/HP | | | | | |
| | | 22-58 | SBKSL | F0.50/SP | UV2.2/2@34" | | | | P5 .4 |
| 3 | | 0-28 | G LS | VF2ND/HP | | | | | |
| | | 28-39 | SBKSL | F0.50/SP | | | | | P5 .4 |

| | | | |
|-------------------------|-----------------------|---------------|--|
| Description | Initial System | Repair System | Other Factors (.1946): Site Classification (.1948): <u>P5</u> Evaluated By: <u>[Signature]</u> Others Present: <u>[Signature]</u> |
| Available Space (.1945) | <u>✓</u> | <u>✓</u> | |
| System Type(s) | <u>PUMP 25' x 25'</u> | | |
| Site LTAR | <u>2</u> | <u>2</u> | |