

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Cumberland Homes

Address: 52 Spring Flowers Dr.

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

50039512

Date: 10/25/17

Building Official: J. Gray

ADDRESS : 52 SPRING FLOWERS DR
 CONTRACTOR : CUMBERLAND HOMES INC
 OWNER : CRESTVIEW DEVELOPMENT LLC
 PARCEL : 09-9567-02- -0006- -11-
 APPL NUMBER: 16-50039512 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/18/2016 09:11 AM JBROCK ----
 CAROLINA SEASONS - 52 SPRING FLOWER DR
 LOT 12

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 PHONE : (910) 892-4345
 PHONE :

STRUCTURE: 000 000 46.6X54 3BDR SLAB W/ GARAGE & PATIO
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY



PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/22/16	TSG	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002913820
	12/22/16	AP	no temp board
B103 01	1/04/17	TSG	R*BLDG FOUND & TEMP SVC POLE VRU #: 002916310
	1/04/17	AP	
P309 01	1/11/17	TSG	R*PLUMB UNDER SLAB VRU #: 002918688
	1/11/17	DA	head test down
P309 02	1/12/17	TSG	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002919348
	1/12/17	AP	T/S: 01/12/2017 08:52 AM LBENNETT
B111 01	1/13/17	TSG	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002919660
	1/13/17	AP	
B104 01	3/02/17	LB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002940237
	3/02/17	AP	T/S: 03/02/2017 11:42 AM LBENNETT
			T/S: 03/02/2017 11:43 AM LBENNETT
A814 01	3/03/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002940229
	3/03/17	AP	52 SPRING FLOWERS DR CAMERON 28326
			T/S: 03/03/2017 02:42 PM SBENNETT
R425 01	3/03/17	TSG	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002940245
	3/03/17	DA	T/S: 03/02/2017 11:44 AM LBENNETT
			REPAIR TOP PLAT AND LADDER TRUSS CUT AT 3" PIPE LEFT SIDE OF STAIRS
R425 02	3/08/17	TSG	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002941904
	3/08/17	AP	T/S: 03/07/2017 08:20 AM BPETRICH
I129 01	3/10/17	TSG	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002943660
	3/10/17	AP	T/S: 03/09/2017 03:17 PM JBROCK
R125 01	3/30/17	TSG	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002951440
	3/30/17	AP	T/S: 03/29/2017 09:51 AM LBENNETT
			STONE PREP
E209 01	6/16/17	TSG	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002985489
	6/16/17	AP	T/S: 06/15/2017 11:26 AM BPETRICH
H824 01	6/22/17	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002989028
	6/22/17	AP	T/S: 06/23/2017 10:32 AM KHINSON
			T/S: 06/23/2017 10:33 AM KHINSON
R429 01	8/03/17	TSG	FOUR TRADE FINAL TIME: 17:00 VRU #: 003007309
	8/03/17	DA	T/S: 08/02/2017 10:47 AM BPETRICH
			1-HANDRAIL REQUIRED TO HAVE MIN 1 1/2" CLEARANCE FROM WALLS AND TRIM IN STAIR AREA 2-WEATHER STRIP ATTIC ACCESS PANEL 3-REAR PORCH GREATER THAN 30" THIS IS MEASURED BEGINING 36"

ADDRESS . . : 52 SPRING FLOWERS DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER . . : CRESTVIEW DEVELOPMENT LLC
PARCEL . . : 09-9567-02- -0006- -11-
APPL NUMBER: 16-50039512 CP NEW RESIDENTIAL (SFD)

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
PHONE : (910) 892-4345
PHONE :

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

R429 02 10/25/17 TI
  OUT FROM PORCH
FOUR TRADE FINAL TIME: 17:00 VRU #: 003043684
T/S: 10/24/2017 11:30 AM DJOHNSON -----

----- COMMENTS AND NOTES -----