

**SOIL/SITE EVALUATION**  
**for ON-SITE WASTEWATER SYSTEM**

Owner: *Stucco Builders* Applicant: *Stucco Builders Inc*  
 Address: *89 Oxfordshire Dr.* Date Evaluated: *12/08/16*  
 Proposed Facility: *3BR SFD* Design Flow (.1949): *360 gal/day*  
 Location of Site: *Hidden Point* Property Recorded: *NCS* Property Size: *3.3 Ac.*  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>L 10%</i>	0-9	<i>Rods SL-Lm</i>	<i>Pt. 555R 555R</i>					
		9-36	<i>SL-Lm</i>	<i>F. 5 P 5 P</i>					<i>PS</i>
		36-112	<i>SAP</i>			<i>36</i>			<i>0.3</i>
2	<i>L 10%</i>	0-15	<i>Rods SL-Lm</i>	<i>Pt. 555R 555R</i>					
		15-44	<i>SL-Lm</i>	<i>F. 5 P 5 P</i>	<i>40</i>	<i>44</i>			<i>PS</i>
									<i>0.3</i>
3	<i>L 10%</i>	0-7	<i>SL-Lm</i>	<i>Pt. 555R 555R</i>					
		7-40	<i>SL-Lm</i>	<i>F. 5 P 5 P</i>	<i>40</i>	<i>40</i>			<i>PS</i>
									<i>0.3</i>

Description	Initial System	Repair System	Other Factors (.1946): <i>None Provision</i> Site Classification (.1948): <i>Provisionally Suitable</i> Evaluated By: <i>Andrew Curran, RPHS-I</i> Others Present: <i>Timmy Muehler, RPHS</i>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<i>2 5/8" Rpt</i>	<i>2 5/8" Rpt</i>	
Site LTAR	<i>0.3</i>	<i>0.3</i>	