

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 11/2/12
 Proposed Facility: 3000 M Design Flow (.1949): 200
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Property Size: Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 10%	0-18	G SL	VFA NS/SP					
	MEASURED	18-48	SBK CL	F2 SS/SP					P5 .4
2		0-18	G SL	VFA NS/SP					
		18-35	SBK SCL	F2 SS/SP					
		35-44	SBK CL	F2 SS/SP	10YR 7/1 @ 4"				P3 .4
3		0-16	G SL	VFA NS/SP					
		16-28	SBK CL	F2 SS/SP					
		28-39"	SBK SCL	F2 SS/SP	10YR 6/1 @ 32"				P3 .4
		39-49"							
4		0-15	G SL	VFA NS/SP					
		15-40	SBK CL	F2 SS/SP	10YR 7/1 @ 34"				P5 .4
		40-49"							

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	AS P2	AS P2	
Site LTAR	.4	.4	

3-75-018