

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Lyon Builders Inc

Address: 16 Oak Lndg
Sanford, NC 27332

Date: 6-21-17

Building Official: [Signature]

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: 16

MFG Home: _____

50042025

ADDRESS . . : 16 OAK LNDG SUBDIV: CAROLINA LAKES

TENANT, NBR: CONF#018859 -LB-11/4/16

CONTRACTOR : LYON BUILDERS INC PHONE : (919) 498-2074

OWNER . . : LYON BUILDERS INC PHONE :

PARCEL . . : 03-9585-06- -0069- - -

APPL NUMBER: 16-50040025 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 10/27/2016 11:23 AM JBROCK -----

CAROLINA LAKES S/D - LOT 69 ON OAK

LANDING OFF OF CAROLINA WAY

STRUCTURE: 000 000 60X40 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00 PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/01/17	TSG	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002939221
	3/01/17	AP	
B103 01	3/22/17	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002947398
	3/22/17	AP	
B105 01	3/23/17	TSG	R*OPEN FLOOR VRU #: 002948214
	3/23/17	AP	
A814 01	4/20/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002961282
	4/19/17	AP	16 OAK LNDG SANFORD 27332
			T/S: 04/19/2017 09:52 AM SBENNETT -----
R425 01	4/20/17	TSG	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002961316
	4/20/17	DA	T/S: 04/19/2017 08:07 AM JBROCK -----
			T/S: 04/20/2017 02:51 PM DJOHNSON -----
			1. SEAL AREA IN GARAGE
			2. NEED INFO ON GARAGE DOOR LVL
			3. HEAD TEST DOWN
			OK TO SIDE AND INSULATE
R425 02	4/27/17	JH	FOUR TRADE ROUGH IN VRU #: 002964864
	4/27/17	AP	
I129 01	4/27/17	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002965473
	4/27/17	AP	T/S: 04/27/2017 01:33 PM BPETRICH -----
			T/S: 04/27/2017 01:34 PM BPETRICH -----
H824 01	5/15/17	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002973238
	5/15/17	AP	T/S: 05/16/2017 10:06 AM KHINSON -----
			T/S: 05/16/2017 10:07 AM KHINSON -----
E209 01	6/16/17	TSG	R*ELEC TEMP POWER CERT VRU #: 002985281
	6/16/17	AP	
R429 01	6/20/17	JH	FOUR TRADE FINAL VRU #: 002986396
	6/20/17	DA	1)Front porch over 30" per code.2)Cover untreated wood around crawl space door.
R429 02	6/21/17	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002987428
			T/S: 06/20/2017 02:10 PM BPETRICH -----

----- COMMENTS AND NOTES -----