

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Durham Building & Electric... PROPERTY LOCATION: 211705 Old Fairground... SUBDIVISION: Leigh Laurel... LOT # 1... Type of Structure: SFD... Proposed Wastewater System Type: 25% Reducted... Projected Daily Flow: 480 GPD... Number of bedrooms: 4... Number of Occupants: 8 max... Pump Required: May be required based on final location and elevations of facilities... Type of Water Supply: Public... Permit valid for: Five years

Authorized State Agent: James E. Markham... Date: 11-21-16... SEE ATTACHED SITE SKETCH... The issuance of this permit by the Health Department in no way guarantees the issuance of other permits.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: Durham Building & Electric... PROPERTY LOCATION: 211705 Old Fairground... SUBDIVISION: Leigh Laurel... LOT # 1... Facility Type: SFD... New... Expansion... Repair... Basement? No... Basement Fixtures? No... Type of Wastewater System: 25% Reducted System... (Initial) Wastewater Flow: 480 GPD... Installation Requirements/Conditions: Number of trenches: 3... Exact length of each trench: 100 feet... Trench Spacing: 7 Feet on Center... Soil Cover: 6 inches... Maximum Trench Depth: 24-28 inches... Pump Requirements: ft. TDH vs. GPM... Aggregate Depth: 6 inches below pipe, 2 inches above pipe, 12 inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markham... Date: 11-21-16... Construction Authorization Expiration Date: 11-21-21

HTE# 16-5-40073

Permit # 29098

Harnett County Department of Public Health Site Sketch

ISSUED TO: Dunham Builders & Blends PROPERTY LOCATION: SR 1705 Old Fairground Rd
 AUTHORIZED STATE AGENT: James E. Markham SUBDIVISION: Leigh Laurel LOT # 1
 Date: 11-21-16

