

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Wynn Construction Inc

Address: 46 Rowland Dr

Fuquay Varina NC 27526

Date: 05/25/2017

Permit Numbers

Building: 16-50040136

Electrical:

Insulation:

Plumbing:

Mechanical:

~~MFG Home~~

Building Official: Brad Sutton

ADDRESS : 46 ROWLAND DR
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER : LITTLE CROSS LLC
 PARCEL : 08-0653- - -0029- -11-
 APPL NUMBER: 16-50040136 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 11/10/2016 10:34 AM JBROCK ----
 AVERY POND #11 OFF OF CHALYBEATE RD

SUBDIV: AVERY POND 32LOTS
 PHONE : (919) 528-1347
 PHONE :

STRUCTURE: 000 000 60X60 4BDR MONO W/ GARAGE & COV POR

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00
 SEPTIC - EXISTING? : NEW TANK
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/20/17	BS	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002934776
	2/20/17	AP	T/S: 02/17/2017 10:07 AM LBENNETT ----- T/S: February 20, 2017 09:40 AM BSUTTON -----
A814 01	2/21/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002935567
	2/21/17	AP	46 ROWLAND DR FUQUAY VARINA 28326 T/S: 02/21/2017 08:55 AM SBENNETT -----
B114 01	2/21/17	KS	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002935583
	2/21/17	DA	T/S: 02/20/2017 01:45 PM LBENNETT ----- T/S: 02/21/2017 10:00 AM KSLATTUM ----- Lug footers miss in garage for beam. 2. Plan calls for continuous footing across garage door. tpole good.
B114 02	2/22/17	BS	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002936144
	2/22/17	DP	T/S: 02/21/2017 01:32 PM JBROCK ----- T/S: February 22, 2017 08:07 AM BSUTTON ----- Not ready
B114 03	2/23/17	BS	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002937134
	2/23/17	AP	T/S: 02/23/2017 11:46 AM JBROCK ----- T/S: February 23, 2017 11:59 AM BSUTTON -----
B104 01	3/20/17	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002947117
	3/20/17	AP	T/S: 03/20/2017 01:18 PM JBROCK -----
R425 01	3/24/17	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002948982
	3/24/17	DA	T/S: 03/23/2017 01:51 PM JBROCK ----- T/S: March 24, 2017 12:20 PM BSUTTON ----- Studs overnotched at fireplace. 2.Improper uplift at girder truss.OK to side/insulate
I129 01	3/29/17	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002950863
	3/29/17	AP	T/S: 03/28/2017 10:56 AM JBROCK ----- T/S: March 29, 2017 01:55 PM BSUTTON -----
R425 02	3/29/17	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002950871
	3/29/17	AP	T/S: 03/28/2017 10:56 AM JBROCK ----- T/S: March 29, 2017 01:55 PM BSUTTON -----
R125 01	4/06/17	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002955342
	4/06/17	AP	T/S: 04/05/2017 01:37 PM JBROCK ----- STONE INSPECTION T/S: April 06, 2017 11:24 AM BSUTTON -----
E209 01	5/05/17	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002968600
	5/05/17	AP	T/S: 05/04/2017 01:14 PM BPETRICH ----- T/S: May 05, 2017 01:26 PM BSUTTON -----
H824 01	5/10/17	AC	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002971224

ADDRESS . : 46 ROWLAND DR
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER . . : LITTLE CROSS LLC
PARCEL . . : 08-0653- - -0029- -11-
APPL NUMBER: 16-50040136 CP NEW RESIDENTIAL (SFD)

SUBDIV: AVERY POND 32LOTS
PHONE : (919) 528-1347
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	5/10/17	AP	T/S: 05/11/2017 09:52 AM KHINSON ----- T/S: 05/11/2017 09:52 AM KHINSON -----
M305 01	5/12/17	BS	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 002972107
	5/12/17	AP	T/S: 05/12/2017 12:47 PM LBENNETT ----- T/S: May 12, 2017 01:52 PM BSUTTON -----
R429 01	5/26/17	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002977445
	<u>5/26/17</u>	<u>ABS</u>	T/S: 05/25/2017 02:05 PM BPETRICH -----

----- COMMENTS AND NOTES -----