

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: ^{WPA} Construction Applicant: Edward Averett
 Address: Lot 17 Mineral Springs Ln Date Evaluated: 12/09/16
 Proposed Facility: 4 BR 5 SD Design Flow (.1949): 480 gal/day
 Location of Site: Avej Pond Property Recorded: Yes Property Size: 0.48 AC
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L-35%	0-14	SL / Gr.	Fr. SSSR SExp					PS
		14-48	SCL / BK	F: SP SExp	37" 7.5SR 311	48+			0.3
2	C-50%	0-16	SL / Gr.	Fr SSSR SExp					PS
		16-48	SCL / BK	F: SP SExp		48+			0.3
3	L-35%	0-10	SL / Gr.	Fr. SSSR SExp					PS
		10-48	SCL / BK	F: SP SExp	30" 8.5SR 311	48+			0.3

Description	Initial System	Repair System	Other Factors (.1946): None Site Classification (.1948): Provisionally Suitable Evaluated By: James Manhart, REHS Others Present: Andrew Curran, REHS-I
Available Space (.1945)	✓	✓	
System Type(s)	25% Red.	25% Red.	
Site LTAR	0.3	0.3	