

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Wyna Construction

Address: 92 Square St

Date: 8-18-17

Building Official:

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

16-700-10145

Ken Stott

ADDRESS : 92 SQUIRE ST SUBDIV: AVERY POND 32LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : LITTLE CROSS LLC PHONE :
 PARCEL : 08-0653- - -0029- -28-
 APPL NUMBER: 16-50040145 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 11/10/2016 10:34 AM JBROCK ----
 AVERY POND #28 OFF OF CHALYBEATE RD

STRUCTURE: 000 000 60X60 4BDR MONO W/ GARAGE & COV POR

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	5/01/17 5/01/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002966026 92 SQUIRE ST FUQUAY VARINA 27526 T/S: 05/01/2017 09:10 AM SBENNETT -----
P309 01	5/01/17 5/01/17	BS AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002966034 T/S: 04/28/2017 02:09 PM BPETRICH ----- T/S: May 01, 2017 10:01 AM BSUTTON ----- Need premise for tpole
B114 01	5/04/17 5/04/17	BS DA	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002967958 T/S: 05/03/2017 01:01 PM BPETRICH ----- T/S: May 04, 2017 10:48 AM BSUTTON ----- Footing behind garage should be continous. 2. Cut out insulation at left garage lug. 3. Need strings over slab
B114 02	5/05/17 5/05/17	BS AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002968626 T/S: 05/04/2017 01:15 PM BPETRICH ----- T/S: May 05, 2017 12:56 PM BSUTTON -----
B104 01	6/12/17 6/12/17	BP AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002983468 T/S: 06/12/2017 08:52 AM BPETRICH ----- T/S: 06/12/2017 09:27 AM BPETRICH -----
R425 01	6/13/17 6/13/17	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002983740 T/S: 06/12/2017 01:37 PM LBENNETT ----- T/S: 06/13/2017 12:41 PM DETAYLOR ----- Need engineer for bored truss above kitchen Completely nail structural guard for plumbing in kitchen Strap stud columns Replace short nails in hangers No test on drain lines Okay to side and insulate
I129 01	6/20/17 6/20/17	BS CA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002986818 T/S: 06/19/2017 02:20 PM LLUCAS ----- T/S: June 20, 2017 01:55 PM BSUTTON -----
R425 02	6/20/17 6/20/17	BS CA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002986826 T/S: 06/19/2017 02:20 PM LLUCAS ----- T/S: June 20, 2017 01:55 PM BSUTTON -----
I129 02	6/21/17 6/21/17	BS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002987345 T/S: 06/20/2017 01:37 PM JBROCK ----- T/S: June 21, 2017 10:45 AM BSUTTON -----
R425 03	6/21/17 6/21/17	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002987352 T/S: 06/20/2017 01:37 PM JBROCK ----- T/S: June 21, 2017 10:45 AM BSUTTON -----

ADDRESS : 92 SQUIRE ST
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : LITTLE CROSS LLC
PARCEL : 08-0653- - -0029- -28-
APPL NUMBER: 16-50040145 CP NEW RESIDENTIAL (SFD)

SUBDIV: AVERY POND 32LOTS
PHONE : (919) 528-1347
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	7/20/17 7/20/17	JLP AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003000338 T/S: 07/19/2017 01:39 PM BPETRICH ----- STONE PREP T/S: 07/20/2017 02:15 PM JPERRY -----
H824 01	7/25/17 7/25/17	AC AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003003969 T/S: 07/26/2017 11:19 AM KHINSON ----- T/S: 07/26/2017 11:20 AM KHINSON -----
M305 01	7/27/17 7/27/17	KS AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003004439 T/S: 07/26/2017 01:44 PM BPETRICH ----- T/S: 07/27/2017 03:49 PM KSLATTUM -----
E209 01	7/31/17 7/31/17	BS AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003005485 T/S: 07/28/2017 01:48 PM BPETRICH ----- T/S: July 31, 2017 11:37 AM BSUTTON ----- Need seperation of ground wires from touching neutral bar in subpanel before final
R429 01	8/18/17 <u>8-18-17</u>	TI <u>KS</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003014362 T/S: 08/17/2017 02:07 PM JBROCK -----

----- COMMENTS AND NOTES -----