

**SOIL/SITE EVALUATION**  
**for ON-SITE WASTEWATER SYSTEM**

Owner: *Same* Applicant: *Dora W. Meredith, Sr.*  
 Address: *Dora Britton Ln* Date Evaluated: *03/17/17*  
 Proposed Facility: *ZBR SFD* Design Flow (.1949): *2409/d*  
 Location of Site: *Courts* Property Recorded: *XC5* Property Size: *4.95 AC*  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1, 2	L < 2%	0-18	GR SL	FR 5HP 5kg					
		18-24	GYBK SCL	FR 5HP 5kg					
		24-30	BK C	FI 5P 5kg	7.5YR 7/1 @ 26"	30			PS
3	L < 2%	0-16	GR SL	FR 5HP 5kg					
		16-20	GYBK SCL	FR 5P 5kg					
		20-30	BK C	FI 5P 5kg	7.5YR 7/1 @ 24"	30			PS
4	L < 2%	0-16	GYBK SL	FR 5HP 5kg					
		16-22	GYBK SCL	FR 5P 5kg					
		22-30	BK C	FI 5P 5kg	7.5YR 7/1 @ 22"	30			PS

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>Provisionally Suitable</i> Evaluated By: <i>Andrew Curran</i> Others Present:
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<i>25% Red.</i>	<i>25% Red.</i>	
Site LTAR		<i>0.45</i>	

\* Repair evaluated 12/01/16