

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Gary Robinson Homes LLC

Address: 267 Saddle Ln
Lillington, NC 27546

Date: 8-24-17

Building Official: [Signature]

Permit Numbers

Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: 16-50040311
MFG Home: _____

ADDRESS : 267 SADDLE LN
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : INVESTMENT CHOICES LLC
 PARCEL : 11-0661- - -0100- -48-
 APPL NUMBER: 16-50040311 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/06/2016 10:20 AM LBENNETT --
 JOHNSON FARMS NO DIRECTIONS GIVEN
 premise # 74013475
 T/S: 03/01/2017 03:27
 PM DJOHNSON --

SUBDIV: JOHNSON FARMS 34 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 46X40 3BDR W/GARAGE SLAB FNSH/BONUS

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/10/17	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002931533
	2/10/17	AP	T/S: 02/09/2017 11:09 AM JBROCK ----- T/S: 02/10/2017 12:05 PM DETAYLOR -----
B103 01	3/02/17	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002939726
	3/02/17	AP	T/S: 03/01/2017 12:30 PM BPETRICH ----- T/S: March 02, 2017 01:42 PM BSUTTON -----
P309 01	3/09/17	DT	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002942852
	3/09/17	AP	T/S: 03/08/2017 02:17 PM LBENNETT ----- T/S: 03/09/2017 10:08 AM DETAYLOR -----
B111 01	3/13/17	KS	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002943868
	3/13/17	DA	T/S: 03/13/2017 02:55 PM KSLATTUM ----- No slab plans in the box
B111 02	3/14/17	KS	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002944619
	3/14/17	AP	T/S: 03/13/2017 02:26 PM BPETRICH ----- THIS IS A REINSPECTION - INSPECTOR COULDN'T FIND PLANS IN BOX. THANK YOU! T/S: 03/14/2017 01:40 PM KSLATTUM -----
A814 01	4/28/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002965671
	4/28/17	AP	267 SADDLE LN LILLINGTON 27546 T/S: 04/28/2017 10:47 AM SBENNETT -----
R425 01	5/01/17	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002965713
	5/01/17	DA	T/S: 04/28/2017 10:48 AM LBENNETT ----- T/S: 05/01/2017 02:58 PM KSLATTUM ----- 1. Garage wing walls need 2 anchors. Nut and washer missing. 2. Dining room wires not fire caulked. 3. Water distribution not complete. No test etc. 4/ Concrete tub drains and washer drain. 5. Mid story guides missing. 6. Fire place not installed. 7 protection plates missing. 8. Al trusses not braced. 9. Roof Boots missing. 10. M1 braces missing. 11. Flash rear door. Do not side nor insulate.
R425 02	5/03/17	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002967370
	5/03/17	DA	T/S: 05/02/2017 01:35 PM BPETRICH ----- T/S: 05/03/2017 02:54 PM DETAYLOR ----- Still missing anchor bolts at wing walls Okay to side and insulate

ADDRESS : 267 SADDLE LN
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : INVESTMENT CHOICES LLC
 PARCEL : 11-0661- - -0100- -48-
 APPL NUMBER: 16-50040311 CP NEW RESIDENTIAL (SFD)

SUBDIV: JOHNSON FARMS 34 LOTS
 PHONE : (910) 977-2562
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	5/05/17 5/05/17	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002968527 T/S: 05/04/2017 12:19 PM LBENNETT ----- T/S: 05/05/2017 03:43 PM DETAYLOR -----
R425 03	5/05/17 5/05/17	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002968535 T/S: 05/04/2017 12:19 PM LBENNETT ----- T/S: 05/05/2017 03:43 PM DETAYLOR -----
H824 01	7/07/17 7/07/17	AC AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002997963 T/S: 07/14/2017 01:16 PM KHINSON ----- T/S: 07/14/2017 01:16 PM KHINSON -----
M305 01	7/24/17 7/24/17	DT AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003001831 T/S: 07/21/2017 01:17 PM JBROCK ----- T/S: 07/24/2017 02:41 PM DETAYLOR -----
P307 01	7/24/17 7/24/17	DT AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003001849 T/S: 07/21/2017 01:17 PM JBROCK ----- T/S: 07/24/2017 02:41 PM DETAYLOR -----
R125 01	7/24/17 7/24/17	DT AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003001823 T/S: 07/21/2017 01:16 PM JBROCK ----- stone inspection
R429 01	8/15/17 8/15/17	BS DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 003012325 T/S: 08/14/2017 01:10 PM BPETRICH ----- T/S: August 15, 2017 01:01 PM BSUTTON ----- Paint rails at front porch. 2. Foam attic doors.
R429 02	8/24/17 <u>8/24/17</u>	TI <u>AP DT</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003016292 T/S: 08/23/2017 09:18 AM BPETRICH -----

COMMENTS AND NOTES

