

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: MCGEAN CONTRACTING + INVEST. PROPERTY LOCATION: TINGEN RD. SUBDIVISION: MARKETPLACE LOT # 88. NEW [X] REPAIR [] EXPANSION []. Type of Structure: SFD (52x34). Proposed Wastewater System Type: 25% REDUCTION SYSTEM. Projected Daily Flow: 480 GPD. Number of bedrooms: 4. Number of Occupants: 8 max. Basement [] Yes [X] No. Pump Required: [] Yes [] No [X] May be required based on final location and elevations of facilities. Type of Water Supply: [] Community [X] Public [] Well. Distance from well: 100 feet. Permit valid for: [X] Five years [] No expiration.

Authorized State Agent: [Signature] Date: 12/14/16 SEE ATTACHED SITE SKETCH. The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: MCGEAN CONTRACTING + INVEST. PROPERTY LOCATION: TINGEN RD. SUBDIVISION: MARKETPLACE LOT # 88. Facility Type: SFD (52x34) [X] New [] Expansion [] Repair. Basement? [] Yes [X] No. Basement Fixtures? [] Yes [X] No. Type of Wastewater System: 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD. (See note below, if applicable []) 25% REDUCTION SYS (Repair)

Installation Requirements/Conditions. Septic Tank Size: 1000 gallons. Pump Tank Size: [] gallons. Number of trenches: 3. Exact length of each trench: 80 feet. Trench Spacing: 9 Feet on Center. Trenches shall be installed on contour at a Maximum Trench Depth of: 24 inches. (Maximum soil cover shall not exceed 36" above the trench bottom) in all directions. Pump Requirements: [] ft. TDH vs. [] GPM. Aggregate Depth: [] inches below pipe [] inches above pipe [] inches total.

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: [Signature] Date: [] [] []. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 12/14/16 Construction Authorization Expiration Date: 12/14/21

HTE# 16-5-40318

Permit # 29128

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: TINGEN RD

ISSUED TO: MCLEAN CONTRACTING + INVEST SUBDIVISION MARKETPLACE LOT # 88

Authorized State Agent: ~~REDACTED~~ REHS (OLIVER TOLKSDORF) Date: 12/24/16

