

COUNTY OF HARNETT  
Building Inspections Department  
Planning Services

Certificate of Compliance: \_\_\_\_\_ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential  
Name: Yarbrough, Andrew Jason

Address: 2117 Sheriff Johnson Rd  
Lillington, NC 27546

Permit Numbers

Building: \_\_\_\_\_  
Electrical: \_\_\_\_\_  
Insulation: \_\_\_\_\_  
Plumbing: \_\_\_\_\_  
Mechanical: 16-50040363  
MFG Home: \_\_\_\_\_

Date: 5-31-17

Building Official: \_\_\_\_\_

[Signature]

ADDRESS : 94419 \*UNASSIGNED  
CONTRACTOR :  
OWNER : YARBROUGH ANDREW JASON &  
PARCEL : 11-0671- - -0073- -10-  
APPL NUMBER: 16-50040363 CP NEW RESIDENTIAL (SFD)

SUBDIV: LILA BETTS MATTHEWS PROP  
PHONE :  
PHONE :

DIRECTIONS : T/S: 12/12/2016 12:19 PM LBENNETT --  
HWY 421 TOWARD BUIES CREEK - LEFT ON  
JOHNSON FARM RD - RIGHT ON SHERIFF  
JOHNSON - PROPERTY ON RIGHT

STRUCTURE: 000 000 46X97 3BDR CRAWL ATTACHED CARPORT

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 02	1/18/17 1/26/17	DT AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002925188 T/S: 01/26/2017 01:36 PM LBENNETT T/S: 01/26/2017 01:36 PM LBENNETT
A814 01	1/27/17 1/27/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002925279 2117 SHERIFF JOHNSON RD LILLINGTON 27546 T/S: 01/27/2017 12:31 PM SBENNETT
B103 01	1/27/17 3/07/17	DT AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002925196 T/S: 01/26/2017 01:37 PM LBENNETT T/S: 03/07/2017 08:08 AM BPETRICH
B105 01	2/01/17 2/01/17	DT AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002926962 T/S: 01/31/2017 08:48 AM JBROCK T/S: 02/01/2017 01:04 PM DETAYLOR
R425 01	3/08/17 3/07/17	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002941896 T/S: 03/07/2017 08:08 AM BPETRICH T/S: 03/07/2017 11:19 AM DETAYLOR 1. Joists above kitchen, family, dining room supposed to be doubled every other, are doubled every third 2. Frame in and fire block top of coat closet around pipe 3. Connect duct to bath exhaust fans 4. Need 3 ft head of water on drain line test 5. Attic platform must extend all the way to access hole 6. Strap stud columns under lvl valleys upstairs 7. Install air barriers behind tub/showers Okay to side and insulate
I129 01	3/29/17 3/30/17	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002950764 T/S: 03/27/2017 04:17 PM BPETRICH T/S: March 30, 2017 02:51 PM BSUTTON Signed off for Deen
R425 02	3/29/17 3/30/17	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002950756 T/S: 03/27/2017 04:17 PM BPETRICH T/S: March 30, 2017 02:51 PM BSUTTON Signed off for Deen
H824 01	5/01/17 5/01/17	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002966943 T/S: 05/02/2017 09:24 AM KHINSON T/S: 05/02/2017 09:24 AM KHINSON
R429 01	5/26/17	DT	FOUR TRADE FINAL TIME: 17:00 VRU #: 002977221

ADDRESS . . : 94419 \*UNASSIGNED  
CONTRACTOR :  
OWNER . . . : YARBROUGH ANDREW JASON &  
PARCEL . . . : 11-0671- - -0073- -10-  
APPL NUMBER: 16-50040363 CP NEW RESIDENTIAL (SFD)

SUBDIV: LILA BETTS MATTHEWS PROP  
PHONE :  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	5/26/17	DA	T/S: 05/25/2017 11:51 AM BPETRICH ----- PLEASE CALL 919.524.0564 WHEN YOU ARE ON THE WAY - SHE WILL MEET YOU ON SITE T/S: 05/26/2017 03:00 PM DETAYLOR ----- Install weather strip and insulation at attic access Need vapor barrier No insulation for floor Okay for power
R429 02	5/31/17	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002979029 T/S: 05/31/2017 01:52 PM LBENNETT ----- T/S: 05/31/2017 01:52 PM LBENNETT -----

----- COMMENTS AND NOTES -----