

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 3802N                      Design Flow (.1949) 360 gpd  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well                       Spring  Other  
 Evaluation Method:  Auger Boring                       Pit                       Cut  
 Type of Wastewater:                       Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-36	G S	VFLN S/MP					
		36-38	SBK SCL	FR SS/SP					PS .4
		38" <sup>11"</sup>	PM						
2		0-36	G S	VFL NS/MP					
		36-40	SBK SCL	FR SS/SP					PS .4
		40" <sup>11"</sup>	PM						
3		0-32	G S	VFL NS/MP					
		32-46	SBK SCL	FR SS/SP					PS .4
4		0-18	G S	VFL NS/MP					
		18-23	SBK C	FR SS/SP					PS .35
		23" <sup>11"</sup>	PM						
5		0-32	G S	VFL NS/MP					
		32-38	SBK SCL	FR SS/SP					PS .4
		38" <sup>11"</sup>	PM						

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948): PS
System Type(s)	PUMPED	ULTRA SURFACE	Evaluated By: DT
Site LTAR	.4	.35	Others Present: -