

Department of Environment, Health and Natural Resources  
 Division of Environmental Health  
 On-Site Wastewater Section

Sheet:  
 Property ID:  
 Lot #:  
 File #:  
 Code:

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Comberland

Owner: Homes, Inc. Applicant: Comberland Homes, Inc.  
 Address: Lot 4 Reserve Dr. Date Evaluated: 01/24/17  
 Proposed Facility: 3BR SFD Design Flow (.1949): 360 gal/day.  
 Location of Site: The Reserve Property Recorded: Yes  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

Property Size: 0.58

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 4%	0-30	GR SL	FR SSSP Sep					PS
		30-48	BK SLL	FI SP Sep		48			G.4
2	L 4%	0-24	GR SL	FR SSSP Sep					PS
		24-48	BK SLL	FI SP Sep		48			G.4
3	L 4%	0-30	GR SL	FR SSSP Sep					PS
		30-48	BK SLL	FI SP Sep	7.5R(1) @ 46"	48			G.4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Provisionally Suitable Evaluated By: Andrew Curran, REHS-I. Others Present: James Menhart, REHS
Available Space (.1945)	✓	✓	
System Type(s)	25% Red	25% Red	
Site LTAR	0.4	0.4	