

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Comfort Homes Inc

Address: 430 Cross Link Dr.

Angier NC 27501

Permit Numbers

Building: 17-50040661

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Date: 06/27/2017

Building Official: Brad Sutton

ADDRESS : 430 CROSS LINK DR SUBDIV: CROSS LINK PLACE
 CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242
 OWNER : CROSSLINK PARTNERS C/O CHARLES PHONE :
 PARCEL : 04-0664- - -0092- -08-
 APPL NUMBER: 17-50040661 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/01/2017 08:29 AM LBENNETT --
 401 N. RIGHT ON CHALYBEATE SPRINGS RD -
 SUBDIVISION ON RIGHT-430 CROSSLINK DR
 PREMISE#47643751
 T/S: 03/09/2017 02:11 PM BPETRICH --
 PREMISE CALLED IN 3/9 2:15PM BP

STRUCTURE: 000 000 51X63 3BDR W/GARAGE W/DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/28/17	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002938736
	2/28/17	AP	T/S: 02/27/2017 01:38 PM LBENNETT ----- T/S: 02/28/2017 03:45 PM DETAYLOR -----
A814 01	3/30/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002951804
	3/30/17	AP	430 CROSS LINK DR ANGIER 27501 T/S: 03/30/2017 09:48 AM SBENNETT -----
B103 01	3/30/17	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002951796
	3/30/17	AP	T/S: 03/29/2017 01:27 PM JBROCK ----- T/S: March 30, 2017 12:57 PM BSUTTON -----
B105 01	4/04/17	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 002953677
	4/04/17	AP	T/S: 04/03/2017 10:02 AM JBROCK ----- T/S: April 04, 2017 10:10 AM BSUTTON -----
R425 01	4/20/17	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002961852
	4/20/17	DA	T/S: April 20, 2017 01:32 PM BSUTTON ----- Have truss company provide a sealed letter that the hangers specified on layout for truss support are suitable with 10Dx1.5 nails instead of full length common nails.
R425 02	4/24/17	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002963130
	4/24/17	AP	T/S: 04/24/2017 03:27 PM DETAYLOR -----
I129 01	4/27/17	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002964930
	4/27/17	AP	T/S: 04/26/2017 02:03 PM JBROCK ----- T/S: April 27, 2017 01:31 PM BSUTTON -----
H824 01	6/23/17	AC	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002989499
	6/23/17	AP	T/S: 06/26/2017 10:02 AM KHINSON ----- T/S: 06/26/2017 10:02 AM KHINSON -----
R429 01	6/27/17	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002989614
			T/S: 06/26/2017 11:41 AM JBROCK -----

COMMENTS AND NOTES