## 29429

## Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit CATES BUILDINGING PROPERTY LOCATION: JUNG DR.
SUBDIVISION TIMEEN POINTE EXPANSION NEW. Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 5 FO (43 ×40) Proposed Wastewater System Type: PUNK TO 35% RESUGION SYSTEM Projected Daily Flow: Number of Occupants: \_ § Number of bedrooms: Basement Yes No Pump Required: No ☐ May be required based on final location and elevations of facilities Type of Water Supply: 
Community Public Well Distance from well feet Permit valid for: Five years Permit conditions: ☐ No expiration The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance ISSUED TO: CATES BUILDING INC PROPERTY LOCATION: JUNO DO SUBDIVISION TINEGN POISTE Facility Type: SFD (43 ×4 8) New Expansion Repair Basement? Yes No Basement Fixtures? \(\sime\) Yes Type of Wastewater System\*\* PUND TO 25 % REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD (See note below, if applicable ) Installation Requirements/Conditions Number of trenches 1 Exact length of each trench 150 feet Trench Spacing: 9 Feet on Center Septic Tank Size LOOO gallons Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6-10 Maximum Trench Depth of: 19 22 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_\_ GPM \_\_\_\_\_ inches below pipe Aggregate Depth: \_\_\_\_\_\_ inches above pipe inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the previsions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date: 3/20/20


## Harnett County Department of Public Health Site Sketch

Authorized State Agent:

PROPERTY LOCATON: JUNO DO2

SUBDIVISION TINGEN POINTE LOT # 173

Authorized State Agent: Date: 3 20 17



JUNO DRIVE