

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Atlanta Construction

Address: 355 Rainmaker St
Linden, NC 28356

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____


Plumbing: _____

Mechanical: 17-50040820

MFG Home: _____

Date: 11/9/17

Building Official: _____



ADDRESS . . : 355 RAINMAKER ST SUBDIV: SWEETWATER 71LOTS
CONTRACTOR : ATLANTIC CONSTRUCTION PHONE : (910) 938-9053
OWNER . . : DIVERSIFIELD INVESTORS INC PHONE :
PARCEL . . : 01-0544- - -0004- -45-
APPL NUMBER: 17-50040820 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 02/27/2017 08:15 AM LBENNETT --
SOUTH ON 401 TURN RIGHT ONTO W REEVES
BRIDGE RD - TURN LEFT ONTO WILL LUCAS
RD - TURN LEFT ONTO HYBRID LN - TURN
RIGHT ONTO RAINMAKER ST

STRUCTURE: 000 000 50X37 4BDR W/GARAGE SLAB

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/28/17	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002950053 T/S: 03/27/2017 10:40 AM BPETRICH ----- T/S: 03/28/2017 09:13 AM DETAYLOR ----- Plans show continuous footer across front of garage
B101 02	3/29/17	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002951010 T/S: 03/28/2017 11:57 AM LBENNETT ----- T/S: 03/29/2017 12:27 PM DETAYLOR -----
H824 01	4/12/17	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002959039 T/S: 04/13/2017 11:31 AM KHINSON ----- T/S: 04/13/2017 11:31 AM KHINSON -----
A814 01	5/01/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002965622 355 RAINMAKER ST LINDEN 28356 T/S: 05/01/2017 09:38 AM SBENNETT -----
B103 01	5/01/17	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002965614 T/S: 04/28/2017 09:15 AM LBENNETT -----
P309 01	5/15/17	DT	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002971943 T/S: 05/12/2017 10:12 AM LBENNETT ----- T/S: 05/15/2017 03:52 PM DETAYLOR -----
B111 01	5/22/17	JH	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002974939 T/S: 05/18/2017 03:55 PM BPETRICH -----
B104 01	6/09/17	DJ	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002983401 T/S: 06/09/2017 04:50 PM DJOHNSON ----- T/S: 06/09/2017 04:51 PM DJOHNSON -----
R425 01	8/18/17	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003013786 T/S: 08/16/2017 02:41 PM BPETRICH ----- 1)Missing roof boots.2)Rafter widder than ridge beams in front dormers & gable in front.3)Missing air barriers in front right bed chase & master bathroom.4)3' head of water on drain line test.5)Missing baffels per code.6)Missing hangers on ceiling joist & 2-2x10 beam in laundry room.7) Missing nails in hangers in laundry room. DO NOT SIDE OR INSULATE
R425 02	8/24/17	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003016078 T/S: 08/22/2017 01:21 PM JBROCK -----

 ADDRESS . . : 355 RAINMAKER ST SUBDIV: SWEETWATER 71LOTS
 CONTRACTOR : ATLANTIC CONSTRUCTION PHONE : (910) 938-9053
 OWNER . . : DIVERSIFIELD INVESTORS INC PHONE :
 PARCEL . . : 01-0544- - -0004- -45-
 APPL NUMBER: 17-50040820 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R425 03	8/28/17	JH	PER LEE FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003017068
	8/28/17	CA	T/S: 08/24/2017 10:06 AM BPETRICH PER LEE
R425 04	8/30/17	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003018454
	8/30/17	DP	T/S: 08/28/2017 01:55 PM DJOHNSON ITEMS #3 & 6 NOT CORRECTED
I129 01	9/06/17	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003020583
	9/06/17	AP	T/S: 09/01/2017 09:17 AM JBROCK
R425 05	9/06/17	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003020609
	9/06/17	AP	T/S: 09/01/2017 09:17 AM JBROCK
M305 01	9/27/17	JH	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003030418
	9/27/17	AP	T/S: 09/26/2017 08:42 AM JBROCK
P307 01	9/27/17	JH	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003030426
	9/27/17	AP	T/S: 09/26/2017 08:42 AM JBROCK
E209 01	10/11/17	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003036795
	10/11/17	DA	T/S: 10/10/2017 08:41 AM BPETRICH 1)Label panel in garage.2)Missing receptacle on counter top to left of stove at opening.3)Need ladder for attic access.
R125 01	10/12/17	JH	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003036753
	10/12/17	AP	T/S: 10/10/2017 08:18 AM LLUCAS LATHE INSPECTION
E209 02	10/18/17	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003040250
	10/18/17	AP	T/S: 10/17/2017 09:55 AM BPETRICH
R429 01	11/07/17	JH	FOUR TRADE FINAL TIME: 17:00 VRU #: 003050200
	11/07/17	DA	T/S: 11/06/2017 01:42 PM JBROCK 1)Steps in garage are more than 3/8" difference & need threshold support.2)AC pad needs to sit on grade.3)Need to cut cap off on vent pipe on back of house.
R429 02	11/09/17	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 003050994
	11/9/17	AP DT	T/S: 11/08/2017 08:04 AM JBROCK

----- COMMENTS AND NOTES -----