

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: McKee Homes LLC
PROPERTY LOCATION: Docs R
SUBDIVISION: OAKMONT
LOT #: 188
Type of Structure: SFD (36x41)
Proposed Wastewater System Type: Pump To 25% Red Sys
Projected Daily Flow: 360 GPD
Number of bedrooms: 3
Number of Occupants: 6 max
Basement: No
Pump Required: Yes
Type of Water Supply: Public
Distance from well: 100 feet
Permit valid for: Five years

Authorized State Agent: [Signature]
Date: 3/20/17
SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: McKee Homes LLC
PROPERTY LOCATION: Docs R
SUBDIVISION: OAKMONT
LOT #: 188
Facility Type: SFD (36x41)
Basement?: No
Basement Fixtures?: No
Type of Wastewater System: Pump To 25% Reducation System
Initial Wastewater Flow: 360 GPD
(See note below, if applicable) Pump To 25% Red Sys (Repair)

Installation Requirements/Conditions
Septic Tank Size: 1000 gallons
Pump Tank Size: 1000 gallons
Number of trenches: 3
Exact length of each trench: 40 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 6-18 inches
Maximum Trench Depth: 18-30 inches
Pump Requirements: _____ ft. TDH vs. _____ GPM
Aggregate Depth: _____ inches below pipe, _____ inches above pipe, _____ inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature]
Date: 3/20/17
Construction Authorization Expiration Date: 3/20/22


HTE# 17-5-40843

Permit # 29428

Harnett County Department of Public Health Site Sketch

ISSUED TO: MCKEE Homes LLC PROPERTY LOCATOR: DOCS RD
SUBDIVISION OAKMONT LOT # 188

Authorized State Agent: ~~REAS (OLIVER TOLKSDORF)~~ Date: 3/20/17



**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address:
 Proposed Facility: 5 Broom Date Evaluated:
 Location of Site: Design Flow (.1949): 360 gal Property Size:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<u>25 25</u>	<u>0-198</u>	<u>GS</u>	<u>VPZNSHP</u>					<u>S, 8</u>
2		<u>0-156</u>	<u>GS</u>	<u>VPZNSHP</u>					<u>S, 8</u>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <u>[Signature]</u> Others Present:
Available Space (.1945)	<u>[Initial]</u>	<u>[Repair]</u>	
System Type(s)	<u>PUMP 25/1000</u>		
Site LTAR	<u>.8</u>	<u>.8</u>	