

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Gary Robinson Homes

Address: 772 Briggs Rd

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

50040589

Date: 8/1/17

Building Official: _____

S. Gully

ADDRESS : 772 BRIGGS RD SUBDIV:
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : MCAULEY AND MCDONALD INVESTMEN PHONE :
PARCEL : 09-9544- - -0009- -15-
APPL NUMBER: 17-50040889 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/06/2017 04:12 PM LBENNETT --
BRIGGS RD - LOT#11 - ADDRESS IS BESIDE
782

STRUCTURE: 000 000 52X58 3BDR W/GARAGE MONO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	5/04/17 5/04/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002967842 772 BRIGGS RD CAMERON 28326 T/S: 05/04/2017 10:35 AM SBENNETT -----
E207 01	5/04/17 5/04/17	TSG AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002967867 T/S: 05/03/2017 11:34 AM LBENNETT -----
P309 01	5/04/17 5/04/17	TSG AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002967859 T/S: 05/03/2017 11:34 AM LBENNETT -----
B114 01	5/05/17 5/05/17	TSG DA	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002968741 T/S: 05/04/2017 03:12 PM LBENNETT ----- full of water and mud
B114 02	5/08/17 5/08/17	TSG AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002969079 T/S: 05/05/2017 01:32 PM JBROCK -----
R425 01	6/01/17 6/01/17	TSG DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002978757 T/S: 05/31/2017 10:31 AM LBENNETT ----- 1-STRAP GARAGE DOOR LVL 2-NAIL GUARD REQUIRED ON GAS LINE PER CODE 3-ANCHOR BOLTS REQUIRED AT FRONT AND REAR DOOR 4-NO PLANS ON LOCATION 5-ATTACH INTERIOR LOAD BEARING WALLS OK TO SIDE AND INSULATE
I129 01	6/05/17 6/05/17	TSG AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002979995 T/S: 06/02/2017 10:21 AM JBROCK -----
R425 02	6/05/17 6/05/17	TSG AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002979987 T/S: 06/02/2017 10:20 AM JBROCK -----
H824 01	6/27/17 6/27/17	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002990984 T/S: 06/28/2017 11:48 AM KHINSON ----- T/S: 06/28/2017 11:48 AM KHINSON -----
E209 01	7/20/17 7/20/17	TSG DA	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003000296 T/S: 07/19/2017 01:10 PM JBROCK ----- DISCONNECT BOX ON RT SIDE OF HOUSE MISSING BREAKER OR COVER IN OPEN SPACE. 2-WATER SERVICE RAN AND COVERED COULD NOT INSPECT. PLEASE PAIR THE STOP PREP INSPECTION WITH ANOTHER INSPECTION
M305 01	7/20/17 7/20/17	TSG AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003000304 T/S: 07/19/2017 01:11 PM JBROCK ----- T/S: 07/20/2017 03:16 PM SGUY -----
E209 02	7/21/17 7/21/17	TSG AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003001062 T/S: 07/20/2017 01:13 PM JBROCK -----
P307 01	7/21/17	TSG	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003001070

ADDRESS : 772 BRIGGS RD SUBDIV:
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : MCAULEY AND MCDONALD INVESTMEN PHONE :
PARCEL : 09-9544- - -0009- -15-
APPL NUMBER: 17-50040889 CP NEW RESIDENTIAL (SPD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	7/21/17 7/25/17 7/25/17	AP JLP AP	T/S: 07/20/2017 01:13 PM JBROCK ----- ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003002243 T/S: 07/24/2017 09:19 AM BPETRICH ----- STONE PREP T/S: 07/25/2017 03:18 PM JPERRY -----
R429 01	7/31/17	TI AP	FOUR TRADE FINAL TIME: 17:00 VRU #: 003005246 T/S: 07/28/2017 09:33 AM LLUCAS ----- LOCKBOX CODE# 5383
R429 02	8/01/17	TI AP	FOUR TRADE FINAL TIME: 17:00 VRU #: 003006277 T/S: 07/31/2017 01:46 PM JBROCK -----

----- COMMENTS AND NOTES -----