

COUNTY OF HARNETT  
Building Inspections Department  
Planning Services

Certificate of Compliance: \_\_\_\_\_ Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: John Tilden Huntington

Address: 489 Raven Rock Rd

\_\_\_\_\_

Date: 6/16/17

Permit Numbers

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

50040923

Building Official: [Signature]

ADDRESS : 489 RAVEN ROCK RD SUBDIV: MALCOM DICKENS PROP  
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331  
 OWNER : HOWINGTON JOHN TILDEN III PHONE :  
 PARCEL : 13-0620- - -0098- -08-  
 APPL NUMBER: 17-50040923 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 03/10/2017 08:24 AM JBROCK ----  
 HWY 421 N 7 MILES TURN RIGHT 1 MILE ON  
 L

**STRUCTURE: 000 000 48X45 3BDR W/ GARAGE & SCR PORCH**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

| TYP/SQ  | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS   |
|---------|---------------------|-------------|--|
| B101 01 | 3/28/17             | TSG         | R*BLDG FOOTING / TEMP SVC POLE VRU #: 002950257  |
|         | 3/28/17             | AP          |  |
| B103 01 | 4/05/17             | TSG         | R*BLDG FOUND & TEMP SVC POLE VRU #: 002954556  |
|         | 4/05/17             | AP          | T/S: 04/05/2017 03:57 PM DJOHNSON -----  |
| P309 01 | 4/11/17             | TSG         | R*PLUMB UNDER SLAB VRU #: 002956983  |
|         | 4/11/17             | AP          | T/S: 04/11/2017 03:22 PM DJOHNSON -----  |
| B111 01 | 4/12/17             | TSG         | R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002957942  |
|         | 4/12/17             | AP          | T/S: 04/12/2017 08:29 AM LBENNETT -----<br>T/S: 04/12/2017 08:29 AM LBENNETT -----   |
| B111 02 | 4/13/17             | TSG         | R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002957884  |
|         | 4/13/17             | AP          | T/S: 04/13/2017 03:41 PM DJOHNSON -----  |
| A814 01 | 4/13/17             | SB          | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002957893  |
|         | 4/13/17             | AP          | 489 RAVEN ROCK RD LILLINGTON 27546<br>T/S: 04/13/2017 09:30 AM SBENNETT -----  |
| R425 01 | 5/08/17             | TSG         | FOUR TRADE ROUGH IN VRU #: 002968998   |
|         | 5/08/17             | DA          | 1-NEED STUD SHOE AT PANEL 2-SEAL TAPE PIPE INSULATION IN<br>GARAGE 3-ATTACH 1/2 LINE FOR HOSE BIB 4-NAIL H-CLIP AT REAR<br>DOOR<br>OK TO SIDE AND INSULATE |
| I129 01 | 5/10/17             | DT          | R*INSULATION INSPECTION VRU #: 002970182   |
|         | 5/10/17             | AP          | T/S: 05/10/2017 03:21 PM DETAYLOR -----  |
| R425 02 | 5/10/17             | DT          | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002970630   |
|         | 5/10/17             | AP          | T/S: 05/10/2017 08:43 AM LBENNETT -----<br>T/S: 05/10/2017 03:21 PM DETAYLOR -----   |
| H824 01 | 5/31/17             | OT          | ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002979383  |
|         | 5/31/17             | AP          | T/S: 06/01/2017 10:09 AM KHINSON -----<br>T/S: 06/01/2017 10:09 AM KHINSON -----   |
| R125 01 | 6/06/17             | TSG         | ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002980522  |
|         | 6/06/17             | AP          | T/S: 06/05/2017 11:42 AM JBROCK -----<br>lathe inspection  |
| R429 01 | 6/13/17             | TSG         | FOUR TRADE FINAL VRU #: 002983631  |
|         | 6/13/17             | DA          | 1-Door alarms or locks on cover required for hot<br>tub. 2-remove paddle fan from over hot tub   |
| R425 03 | 6/16/17             | TSG         | FOUR TRADE ROUGH IN VRU #: 002985577   |