

HTE# 17-S-40973

Harnett County Department of Public Health

29351

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Royal Oaks BID Co group PROPERTY LOCATION: 51448 ATKINS RD
 NEW REPAIR EXPANSION SUBDIVISION: ATKINS VILLAGE LOT # 34
 Type of Structure: SFD Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 25" Reducer
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 1 Number of Occupants: 2 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: James E. Markham Date: 4-12-17 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Royal Oaks BID Co group PROPERTY LOCATION: 51448 ATKINS RD
 Facility Type: SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25" Reducer System (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable)
Pumpman Monitored 25" Reducer (Repair)
Installation Requirements/Conditions
 Septic Tank Size 1200 gallons Number of trenches 1
 Pump Tank Size 1200 gallons Exact length of each trench 360 feet Trench Spacing: 7 Feet on Center
 Trenches shall be installed on contour at a Soil Cover: 4 inches
 Maximum Trench Depth of: 12" inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/- 1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
 _____ inches above pipe
 _____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH


Authorized State Agent: James E. Markham Date: 4-12-17
 Construction Authorization Expiration Date: 4-12-22

HTE# 17-5-40973

Permit # 29351

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: 581448 ATKINS RD
ISSUED TO: Royal Oaks Bid Co SUBDIVISION ATKINS Village LOT # 34
Authorized State Agent: James E. Marshall Date: 4-12-17



Follow Consultants
Layout + Flagged
AREA

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: **Royal Oaks Lot 84**
 Address: _____ Date Evaluated: **4-10-17**
 Proposed Facility: **SFP** Design Flow (.1949): **180** Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1.2	G^{30%}	0-20	SL	FLGMSNP					PS
		20-40	XL	FLGMSNP	36-38				PS
3	G^{30%}	0-18	SL	FLGMSNP					
		18-30	SL	FLGMSNP	24-28	1764P 3/1			.35

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): PS
System Type(s)	2500	2800	Evaluated By: JH
Site LTAR	.35	.35-4	Others Present: