
ADDRESS . . : 115 SQUIRE ST SUBDIV: AVERY POND 32LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . . : LITTLE CROSS LLC PHONE :
 PARCEL . . . : 08-0653- - -0029- -23-
 APPL NUMBER: 17-50041015 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/23/2017 10:32 AM JBROCK ----
 AVERY POND #23
 T/S: 07/06/2018 12:27 PM DJOHNSON --
 premise no 75389877

STRUCTURE: 000 000 60X60 4BDR CRAWL W/ GARAGE & COV PORCH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	3/08/18	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003098712
	3/08/18	AP	115 SQUIRE ST FUQUAY VARINA 27526 T/S: 03/08/2018 08:44 AM SBENNETT -----
B101 01	3/08/18	MC	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 003098704
	3/08/18	AP	T/S: 03/07/2018 09:11 AM BPETRICH ----- T/S: 03/08/2018 02:58 PM MCOOK ----- 1. called in at 9:29am
B103 01	3/20/18	MC	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003103165
	3/20/18	AP	T/S: 03/19/2018 10:32 AM BPETRICH ----- T/S: 03/20/2018 03:40 PM MCOOK -----
B105 01	3/29/18	MC	R*OPEN FLOOR TIME: 17:00 VRU #: 003107653
	3/29/18	AP	T/S: 03/28/2018 09:13 AM JBROCK ----- T/S: 03/29/2018 11:45 AM KSLATTUM ----- 5 pole footings. T/S: 03/29/2018 04:04 PM DJOHNSON -----
B104 01	4/24/18	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003118239
	4/24/18	AP	T/S: 04/24/2018 08:39 AM JBROCK -----
R425 01	4/30/18	MC	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003120151
	4/30/18	DA	T/S: 04/27/2018 11:23 AM DJOHNSON ----- T/S: 04/30/2018 03:25 PM MCOOK ----- 1. properly nail together g2g truss bottom cord 2. block osb on left garage wall and pf garage 3. install 2sc under double joist over garage header 4. properly nail ledger at double and triples in garage 5. install walls under stairs in garage 6. install windows in master shower 7. missing nailplate at ref water line 8. fireblock gable end at ceiling in bonus room
I129 01	5/02/18	MC	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003121779
	5/02/18	AP	T/S: 05/01/2018 11:28 AM BPETRICH ----- T/S: 05/02/2018 03:41 PM MCOOK -----
R425 02	5/02/18	MC	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003121761
	5/02/18	AP	T/S: 05/01/2018 11:27 AM BPETRICH ----- T/S: 05/02/2018 03:41 PM MCOOK -----
M305 01	5/11/18	MC	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003126224
	5/11/18	AP	T/S: 05/10/2018 10:53 AM JBROCK ----- T/S: 05/11/2018 03:15 PM MCOOK -----
H824 03	5/16/18	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003128717

ADDRESS . : 115 SQUIRE ST SUBDIV: AVERY POND 32LOTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER . . : LITTLE CROSS LLC PHONE :
PARCEL . . : 08-0653- - -0029- -23-
APPL NUMBER: 17-50041015 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	5/16/18	DA	PER JAMES MANHART HOLD FOR PUMP AND ALARM DBOX 910-893-7547 T/S: 05/16/2018 10:47 AM KHINSON -----
H824 02	5/16/18	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003128709
	5/16/18	DA	PER JAMES MANHART HOLD FOR PUMP AND ALARM D-BOX! 910-893-7547
			PER JAMES MANHART HOLD FOR PUMP AND ALARM DBOX 910-893-7547
H824 01	5/16/18	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003128691
	5/16/18	DA	T/S: 05/16/2018 10:43 AM KHINSON ----- T/S: 05/16/2018 10:43 AM KHINSON -----
R125 01	5/23/18	MC	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003130515
	5/23/18	AP	T/S: 05/22/2018 08:41 AM JBROCK ----- stone inspection
			T/S: 05/23/2018 03:23 PM MCOOK -----
E209 01	6/08/18	KS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003137338
	6/08/18	AP	T/S: 06/07/2018 11:14 AM JBROCK ----- T/S: 06/08/2018 02:32 PM KSLATTUM -----
H824 04	7/06/18	AC	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003148962
	7/06/18	AP	T/S: 07/06/2018 10:59 AM KHINSON ----- T/S: 07/06/2018 10:59 AM KHINSON -----
R429 01	7/09/18	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 003149044
	<u>11</u>	<u>AB</u>	T/S: 07/06/2018 12:27 PM DJOHNSON -----

----- COMMENTS AND NOTES -----