

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Wynn Construction Inc. PROPERTY LOCATION: 521429 Claybeate RD. SUBDIVISION: Avery Pond LOT # 23. Type of Structure: SFD. Proposed Wastewater System Type: 25% Red (Accepted). Projected Daily Flow: 480 GPD. Number of Occupants: 8 max. Permit valid for: 5 years.

Authorized State Agent: James E. Mashburn Date: 2-20-18 SEE ATTACHED SITE SKETCH. The issuance of this permit by the Health Department in no way guarantees the issuance of other permits.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: Wynn Construction Inc. PROPERTY LOCATION: 521429 Claybeate RD. SUBDIVISION: Avery Pond LOT # 23. Facility Type: SFD. Type of Wastewater System: 25% Reductive System. (Initial) Wastewater Flow: 480 GPD.

Installation Requirements/Conditions: Number of trenches 3, Septic Tank Size 1200 gallons, Pump Tank Size 1200 gallons, Trench Spacing 9 Feet on Center, Soil Cover 6 inches, Pump Requirements: 6 inches below pipe, 2 inches above pipe, 12 inches total.

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site.

Authorized State Agent: James E. Mashburn Date: 2-20-18 Construction Authorization Expiration Date: 2-20-23

HTE# 17-5-41015212

Permit # 29640

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Wynn Construction INC PROPERTY LOCATOR: 511423 Chalybeate RD  
SUBDIVISION Avery Pond LOT # 23

Authorized State Agent: James E. Marshall JR TREAS Date: 2-20-18

