

HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH Well Abandonment Permit

Permit Number: 29484

Application Number: 17-5-42423

Applicant Name: Wynn Construction, Inc

Address: 7201 Creedmoor Road, Suite 147 Raleigh, NC 27613

Type of Well: Hand Dug **Total Depth:** 10ft **Diameter:** 48in **Grouted:** No **Static Water Level:** None


Directions to Site: Hwy 401 N. toward Fuquay-Varina. Left on Chalybeate Rd. Left onto Avery Pond Drive. Location on right Lot 67 is 4th lot on right.

Agent of the State *[Signature]* Date: 10-23-17

Abandonment Procedure: Abandonment Procedure: 1. Remove all plumbing or piping into the well, along with any obstructions inside the well; 2. Remove as much of the well tile casing as possible, but no less than to a depth of three feet below land surface; 3. remove all soil or other subsurface material present down to the top of the remaining well casing, and extending to a width of at least 12 inches outside of the well casing on all sides; 4. Fill the well up to the top of the remaining casing with cement grout, concrete grout, bentonite grout, dry clay, or material excavated during drilling of the well and then compacted in place; 5. Pour a one foot thick concrete grout or cement grout plug that fills the entire excavated area about the top of the casing, including the area extending on all sides of the casing out to a width of at least 12 inches on all sides; 6. Complete the abandonment process by filling the remainder of the well above the concrete or cement plug with additional concrete grout, cement grout, or soil. A record of the abandonment must be submitted within 30 days of abandonment.

Note: Contact Harnett County Environmental Health for appointment prior to beginning of well abandonment procedure.

Well must be abandoned by a Certified North Carolina well driller/contractor.



[Signature]
Property Owner's or Owners Legal Representative Signature Required

10/25/17
Date

Harnett County Department of Public Health

Well Abandonment Permit Application

APPLICANT INFORMATION

Wynn Construction, Inc. 919-795-3922 (mobile)
Applicant/Owner (919) 528-1347 Phone Number
7201 Creedmoor Rd., Suite 147 Raleigh, NC 27613
Street Address, City, State, Zip Code

PROPERTY INFORMATION

Street Address 94 Avery Pond Dr. Subdivision/Lot # Avery Pond Lot 67
Parcel # _____ PIN # 0653-47-3135.000

Directions to the Site

Hwy 401N Turn left on Chalybente Rd.
Avery Pond on Left. Lot 67 is 4th lot on Right

Brief description of the well location (ex. front yard, behind out building, front yard, etc.)
Left Rear Corner of Property

*Please include a Site Plan of your property showing the location of the well. If the well is underground, it must be uncovered prior to the department's site visit.

Please Complete the Following Information:

Date Well Was Constructed Existing Grouted: Yes No
Above Ground or Below Ground Total Depth of Well 10'
Well Type: Drilled Bored Hand dug Diameter _____ inches

I have thoroughly read and completed this Application and certify that the information provided herein is true, complete and correct to the best of my knowledge and is given in good faith. Representatives of the Harnett County Health Department and State Officials are granted right of entry to conduct necessary inspections to determine compliance with applicable rules.

I understand that I am solely responsible for the proper identification and labeling of all property lines, underground utility lines, and making the site accessible so that a well can be properly constructed according to the permit.

[Signature]
Property Owner's or Owner's Legal Representative Signature Required

10/16/17
Date

If you have any questions please contact Environmental Health Division at 910-893-7547

10-16-17
N