

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Atlantic Construction

Address: 97 Folly Ct

Date: 3-5-18

Building Official: James Hall

Permit Numbers

Building: _____

Electrical: 17-50041035

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

ADDRESS : 97 FOLLY CT SUBDIV: SWEETWATER 71LOTS
CONTRACTOR : ATLANTIC CONSTRUCTION PHONE : (910) 938-9053
OWNER : DIVERSIFIELD INVESTORS INC#52 PHONE :
PARCEL : 01-0544- - -0004- -60-
APPL NUMBER: 17-50041035 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/27/2017 09:25 AM DJOHNSON --
SWEETWATER LOT 52
T/S: 03/27/2017 09:36 AM DJOHNSON --

STRUCTURE: 000 000 40X42 4BD 3.5BA SLAB W/GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	10/09/17 10/06/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003034857 97 FOLLY CT LINDEN 28356 T/S: 10/06/2017 10:01 AM SBENNETT -----
B101 01	10/09/17 10/09/17	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 003034865 T/S: 10/05/2017 10:29 AM LLUCAS ----- T-POLE PASSED -----
B103 01	10/16/17 10/16/17	JH DA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003039138 T/S: 10/13/2017 09:40 AM BPETRICH ----- 1)Missing anchor bolts on right side of foundation wall.2)Remove dirt from topof footings for inspection inside & out.
B103 02	10/17/17 10/17/17	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003040359
P309 01	10/24/17 10/24/17	JH AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003043486 T/S: 10/24/2017 09:35 AM BPETRICH ----- T/S: 10/24/2017 09:35 AM BPETRICH -----
B111 01	10/30/17 10/30/17	JH AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 003045069 T/S: 10/26/2017 09:15 AM BPETRICH -----
B104 01	11/30/17 11/30/17	BP AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003059979 T/S: 11/30/2017 10:47 AM BPETRICH ----- T/S: 11/30/2017 10:47 AM BPETRICH -----
R425 01	12/05/17 12/05/17	JH DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003061967 T/S: 12/04/2017 12:57 PM LLUCAS ----- 1)Missing structural nail guard over panel in garage.2)Missing air barrier at water heater in garage.3)Missing anchor bolts,to right of back door, at kitchen sink, at refrig & each side of front door.4)Fire caulk hole in top plate in kitchen pantry.5)Missing roof boots.6)3'head of water on drain line test.7)Loose oeb in middle bed on back wall & end wall in master bed.8)Fire caulk dryer duct at top plate.9)Label dryer duct length per code.
R425 02	12/08/17 12/08/17	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003063625 T/S: 12/07/2017 09:16 AM BPETRICH ----- T/S: 12/08/2017 02:33 PM DETAYLOR ----- Structural nail guard missing nails
I129 01	12/12/17	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003065000

ADDRESS : 97 FOLLY CT SUBDIV: SWEETWATER 71LOTS
CONTRACTOR : ATLANTIC CONSTRUCTION PHONE : (910) 938-9053
OWNER : DIVERSIFIELD INVESTORS INC#52 PHONE :
PARCEL : 01-0544- - -0004- -60-
APPL NUMBER: 17-50041035 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	12/12/17	AP	T/S: 12/11/2017 01:41 PM BPETRICH -----
R425 03	12/12/17	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003064995
	12/12/17	AP	T/S: 12/11/2017 01:41 PM BPETRICH -----
H824 01	12/19/17	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003074556
	12/19/17	AP	T/S: 01/09/2018 04:46 PM KHINSON -----
			T/S: 01/09/2018 04:46 PM KHINSON -----
M305 01	12/29/17	JH	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003071453
	12/29/17	AP	T/S: 12/28/2017 10:30 AM BPETRICH -----
P307 01	12/29/17	JH	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003071446
	12/29/17	AP	T/S: 12/28/2017 10:30 AM BPETRICH -----
R125 01	1/25/18	JH	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003079415
	1/25/18	CA	T/S: 01/23/2018 01:28 PM DJOHNSON -----
			PER LEE -----
R125 02	1/26/18	JH	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003080702
	1/26/18	AP	T/S: 01/25/2018 10:06 AM JBROCK -----
			LATH INSPECTION -----
E209 01	2/06/18	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003084183
	2/06/18	AP	T/S: 02/01/2018 09:18 AM BPETRICH -----
R429 01	3/01/18	JH	FOUR TRADE FINAL TIME: 17:00 VRU #: 003095353
	3/01/18	CA	T/S: 02/27/2018 02:44 PM LLUCAS -----
			PER LEE -----
R429 02	3/05/18	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 003096435
	3-5-18	AP TH	T/S: 03/01/2018 01:09 PM JBROCK -----

COMMENTS AND NOTES