

ADDRESS : 190 ROCKY WATER DR
CONTRACTOR :
OWNER : GREGORY JERRY D & AMY W
PARCEL : 05-0633- - -0036- -08-
APPL NUMBER: 17-50041066 CP NEW RESIDENTIAL (SFD)

SUBDIV: PHELMA B ROGERS & WILLIAM H
PHONE :
PHONE : (919) 552-0659

DIRECTIONS : T/S: 03/31/2017 11:59 AM DJOHNSON --
401 N TO CHRISITAN LIGHT RD THEN LEFT
FOR A LITTLE WAYS AND THEN LEFT ONTO
ROCKY WATER DR BUILDING SITE IS 1.4
MILES ON RIGHT.
T/S: 05/22/2017 10:59 AM DJOHNSON --
*****PREMISE NO 99050941*****


STRUCTURE: 000 000 72.6X76.6 3 BR ATT 2 CAR GARAGE CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	4/19/17 4/19/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002960888 190 ROCKY WATER DR FUQUAY VARINA 27526 T/S: 04/19/2017 10:11 AM SBENNETT -----
B101 01	5/03/17 5/03/17	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002966927 T/S: 05/03/2017 02:54 PM DETAYLOR -----
B103 01	5/22/17 5/22/17	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002975027 T/S: May 22, 2017 10:24 AM BSUTTON ----- Tpole ok. Need premise number
B105 01	6/01/17 6/01/17	BS AP	R*OPEN FLOOR VRU #: 002978716 As early as possible would be great. Thanks! T/S: June 01, 2017 09:22 AM BSUTTON -----
R425 01	7/17/17 7/17/17	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002997872 T/S: 07/14/2017 12:36 PM LLUCAS ----- T/S: 07/17/2017 11:08 AM DETAYLOR ----- Need extra rafters/ceiling ties or engineering for attic Missing hangers for double and triple joists in garage Plans call for 7 jack studs under each side of garage lvls Okay to brick and insulate
I129 01	7/28/17 7/28/17	TI TI	R*INSULATION INSPECTION VRU #: 003004173
R425 02	7/28/17 7/28/17	TI TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003005147 T/S: 07/27/2017 03:43 PM BPETRICH -----

----- COMMENTS AND NOTES -----



Howerton Services. PLLC.

License #: P-1716
2108 Karns Place
Raleigh, NC 27614
(919) 270-3460

July 19, 2017

Subject: Gregory Residence
Rocky Waters Drive
Fuquay Varina, NC 27526
Harnett County Permit #: 17-50041066
Plan Revision

Based on the request of the homeowner, the following items were modified from the Structural plan prepared by John F. Deal. PE:

- Sheets S1, S2, & S3 – All floor joists, ceiling joists, and rafters are installed at 16" o.c.

This revision meets all the requirements of the 2012 North Carolina Building Code for Residences.



Joel S. Howerton

07 20 2017