

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: *Some* Applicant: *Lumber and Homes, Inc*  
 Address: *Lot 3 The Reserve* Date Evaluated: *04/18/17*  
 Proposed Facility: *4812 SLD* Design Flow (.1949): *480 GPD*  
 Location of Site: *Rollins Rd.* Property Recorded: *Yes* Property Size: *0.57 AC*  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 3%	0-38	BR SL	FR SSSP SEP					PS
		38-48	BR SCL	FI SP SEP	SYR 6/2 @ 46"	48			0.4
2	L 4%	0-36	BR SL	FR SSSP SEP					PS
		36-48	BR SCL	FI SP SEP		48			0.4
3	L 4%	0-34	BR SL	FR SSSP SEP					PS
		34-48	BR SCL	FI SP SEP	SYR 6/2 @ 44"	48			0.4
4	L 3%	0-38	BR SL	FR SSSP SEP					PS
		38-48	BR SCL	FI SP SEP	SYR 4/2 @ 46"	48			0.4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>Provisionally suitable</i> Evaluated By: Others Present: <i>Andrew Lugin, PEHS</i>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<i>25% rec</i>	<i>25% rec</i>	
Site LTAR	<i>0.4</i>	<i>0.4</i>	