

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential
Name: Gary Robinson Home
Address: 241 Saddle Lane
Littlington, NC

Permit Numbers

Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: 17-4041165
MFG Home: _____

Date: 3-5-18

Building Official: K. Slatt

ADDRESS : 241 SADDLE LN
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : INVESTMENT CHOICES LLC
 PARCEL : 11-0661- - -0100- -47-
 APPL NUMBER: 17-50041165 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/17/2017 04:32 PM BPETRICH --
 241 SADDLE LANE ROAD LILLINGTON 27546
 JOHNSON FARMS #47
 PREMISE#47399158
 T/S: 08/01/2017 03:36 PM DJOHNSON --
 T/S: 08/01/2017 03:38 PM DJOHNSON --
 ***NEW PREMISE NO GIVEN TO ME BY
 PATRICK 47397158*****

SUBDIV: JOHNSON FARMS 34 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 40X36 4BDRM CRAWL W/GAR W/FIN BON W/CLST

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	7/17/17 7/17/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002997724 241 SADDLE LILLINGTON 27546 T/S: 07/17/2017 09:04 AM SBENNETT -----
B101 01	7/17/17 7/17/17	JLP DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002997732 T/S: 07/14/2017 11:08 AM LLUCAS ----- Muck out footing and address compaction
B101 02	7/24/17 7/24/17	DT DA	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 003001872 T/S: 07/21/2017 01:18 PM JBROCK ----- T/S: 07/24/2017 02:42 PM DETAYLOR ----- Footing must be re-formed, engineer letter must be on site
B101 03	7/25/17 7/25/17	DT AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 003002557 T/S: 07/24/2017 12:54 PM LLUCAS ----- PLEASE SIGN OFF ON PREVIOUS T/S: 07/25/2017 11:08 AM DETAYLOR -----
B103 01	8/03/17 8/03/17	BS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003007341 T/S: 08/02/2017 11:58 AM LLUCAS ----- T/S: August 03, 2017 12:57 PM BSUTTON -----
B105 01	8/09/17 8/09/17	DT AP	R*OPEN FLOOR TIME: 17:00 VRU #: 003009768 T/S: 08/08/2017 12:24 PM LLUCAS ----- T/S: 08/09/2017 11:28 AM DETAYLOR -----
R425 01	9/07/17 9/08/17	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003021235 T/S: 09/05/2017 11:22 AM BPETRICH ----- T/S: 09/05/2017 03:36 PM BPETRICH ----- T/S: 09/08/2017 09:48 AM DETAYLOR -----
R425 02	9/11/17 9/11/17	JLP DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003023009 T/S: 09/08/2017 12:30 PM LLUCAS ----- 1-Attach loose house wrap. 2-Nail stud on masterbed/stair wall. 3-Fire caulk opening in laundry room/master bath chase. OK TO INSULATE
I129 01	9/14/17 9/14/17	JLP AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003024734 T/S: 09/13/2017 12:25 PM DJOHNSON ----- T/S: 09/14/2017 03:07 PM JPERRY -----
R425 03	9/14/17	JLP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003024726

ADDRESS : 241 SADDLE LN
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : INVESTMENT CHOICES LLC
 PARCEL : 11-0661- - -0100- -47-
 APPL NUMBER: 17-50041165 CP NEW RESIDENTIAL (SFD)

SUBDIV: JOHNSON FARMS 34 LOTS
 PHONE : (910) 977-2562
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	9/14/17	AP	T/S: 09/13/2017 12:25 PM DJOHNSON ----- T/S: 09/14/2017 03:07 PM JPERRY -----
M305 01	10/20/17 10/20/17	DT AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003041530 T/S: 10/19/2017 09:05 AM BPETRICH ----- T/S: 10/20/2017 01:08 PM DETAYLOR -----
P307 01	10/20/17 10/20/17	DT AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003041522 T/S: 10/19/2017 09:04 AM BPETRICH ----- T/S: 10/20/2017 01:08 PM DETAYLOR -----
R125 01	11/15/17 11/15/17	DT AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003053121 T/S: 11/14/2017 01:36 PM BPETRICH ----- STONE PREP T/S: 11/15/2017 03:32 PM DETAYLOR -----
E104 01	12/20/17 12/20/17	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003069523 T/S: 12/20/2017 01:40 PM JBROCK -----
E209 01	12/22/17 12/22/17	DT DA	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003069721 T/S: 12/20/2017 03:53 PM DJOHNSON ----- LOCK BOX CODE IS 5383 T/S: 12/22/2017 12:13 PM DETAYLOR ----- Highest breaker in panel must be within 6'7 of walking surface
E209 02	1/17/18 1/19/18	DT DA	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003076999 T/S: 01/16/2018 01:31 PM BPETRICH ----- LOCK BOX CODE IS 5383 T/S: 01/19/2018 03:58 PM DETAYLOR -----
E209 03	1/29/18 1/29/18	DT AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003081288 T/S: 01/25/2018 01:58 PM JBROCK ----- T/S: 01/29/2018 03:10 PM DETAYLOR -----
H824 01	2/28/18 2/28/18	AC AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003096948 T/S: 03/02/2018 11:24 AM KHINSON ----- T/S: 03/02/2018 11:24 AM KHINSON -----
R429 01	3/05/18 <u>3-5</u>	TA <u>AP</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003097045 T/S: 03/02/2018 01:21 PM LLUCAS ----- LOCKBOX#5383

COMMENTS AND NOTES