

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 4300                      Design Flow (.1949): 480 gpd                      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:                       Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-14	G SL	VFA NS/MP					
		14-30	SBX C	FA S/SP					
		30-40	SBX SCL <sup>x</sup>	FA SS/MP					PS .5
		40-71	SBX <sup>HT</sup> SCL <sup>HT</sup>	VFA NS/MP	CR 2 @ 60"				
2		0-20	C S1	VFA NS/MP					
		20-33	SBX C	FA S/SP					
		33-40	SBX SCL	FA SS/MP					PS .5
		40-60 <sup>HT</sup>	G S	VFA NS/MP					
3		0-12	G SL	VFA NS/MP					
		12-36	SBX C	FA S/SP					
		36-46	SBX SCL	FA SS/MP					PS .5
		46-66	G S	VFA NS/MP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>PS</u> Evaluated By: <u>OT</u> Others Present: <u>-</u>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<u>25% RGS</u>		
Site LTAR	<u>.5</u>	<u>.5</u>	

1x240' 36"-46"                      Pump?