

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: W. Weatherline

Address: 155 Fairfax Dr

Date: 9/14/17

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Building Official: [Signature]

50041243

ADDRESS : 155 FAIRFAX DR SUBDIV: PITTMAN CROSSING PH2 22LOTS
 CONTRACTOR : WEAVER HOMES, INC. PHONE : (910) 630-2100
 OWNER : ALLIED DEVELOPMENT INC PHONE :
 PARCEL : 03-9588- - -0003- -14-
 APPL NUMBER: 17-50041243 CP NEW RESIDENTIAL (SFD) /
 DIRECTIONS : T/S: 04/26/2017 09:10 AM BPETRICH --
 HWY 27 WEST - RIGHT ON BARBECUE CHURCH
 ROAD - RIGHT ON ROSSER PITTMAN ROAD -
 LEFT INTO PROJECT.
 PITTMAN CROSSING #8

STRUCTURE: 000 000 57X62 4 BBRN CRAWL W/GARAGE W/DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/26/17 5/26/17	TSG AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002977274
B103 01	6/06/17 6/06/17	TSG DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 002980571 RIGHT SIDE PIER BEHIND PORCH OFF CENTER 1/3 OF FOOTER AND HAS NO PROJECTION ON RIGHT SIDE.
A814 01	6/06/17 6/06/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002980589 155 FAIRFAX DR SANFORD 27332 T/S: 06/06/2017 09:46 AM SBENNETT -----
B103 02	6/08/17 6/08/17	TSG AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002982122
B105 01	6/14/17 6/14/17	TSG AP	R*OPEN FLOOR VRU #: 002984128
R425 01	7/11/17 7/11/17	TSG DA	FOUR TRADE ROUGH IN VRU #: 002994807 head test low ok to insulate and side
I129 01	7/13/17 7/13/17	TSG AP	R*INSULATION INSPECTION VRU #: 002994816 ----
R425 02	7/13/17 7/13/17	TSG AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002995710 T/S: 07/11/2017 11:05 AM BPETRICH -----
H824 01	7/27/17 7/27/17	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003005311 T/S: 07/28/2017 09:41 AM KHINSON ----- T/S: 07/28/2017 09:41 AM KHINSON -----
R125 01	8/01/17 8/01/17	TSG AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003006210 T/S: 07/31/2017 01:38 PM BPETRICH ----- STONE PREP T/S: 08/01/2017 02:56 PM SGUY -----
E209 01	8/14/17 8/14/17	TSG AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003011731 T/S: 08/11/2017 01:53 PM JBROCK ----- T/S: 08/14/2017 02:39 PM SGUY -----
R429 01	9/01/17 9/01/17	JH DA	FOUR TRADE FINAL VRU #: 003020313 2) Missing energy certificate per code. 2) Wind load label for garage doors. 3) Hole in ceiling in living room at bookcase. 4) Missing return grill up stairs. 5) Need 20 x 30 access opening for AHU in attic for removal per code. 6) Weatherstrip access door in attic.
R429 02	9/14/17	TI	FOUR TRADE FINAL VRU #: 003024792

ADDRESS . : 155 FAIRFAX DR SUBDIV: PITTMAN CROSSING PH2 22LOTS
CONTRACTOR : WEAVER HOMES, INC. PHONE : (910) 630-2100
OWNER . . . : ALLIED DEVELOPMENT INC PHONE :
PARCEL . . : 03-9588- - -0003- -14-
APPL NUMBER: 17-50041243 CP NEW RESIDENTIAL (SPD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

J GAP

COMMENTS AND NOTES
