

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Gregory Inc

Address: 70 Young Rd
Angier, NC 27501

Date: 7-20-17

Building Official: _____

Permit Numbers
Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: 1750041250
MFG Home: _____

ADDRESS : 70 YOUNG RD
 CONTRACTOR : GREGORY INC
 OWNER : WESTBROOK MILTON & WIFE
 PARCEL : 07-0692- - -0093- -02-
 APPL NUMBER: 17-50041250 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/26/2017 02:37 PM JBROCK ----
 27 INTO COATS TURN L AT LIGHT 55 HWY
 HEAD TO ANGLIER TURN R ON MAPLE RD GO TO
 STOP SIGN TURN L ONTO CARSON GERGORY RD
 TURN R ONTO LANGDON RD TURN L ONTO
 YOUNG RD WILL BE 2ND LOT ON R

STRUCTURE: 000 000 33X44 3BDR CRAWL W/ DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 30.00
 SEPTIC - EXISTING? : EXT TANK
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| A814 01 | 5/26/17 | SB | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002977247 |
| | 5/26/17 | AP | 70 YOUNG RD ANGLIER 27501 |
| | | | T/S: 05/26/2017 10:04 AM SBENNETT ----- |
| B101 01 | 5/26/17 | DT | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002977239 |
| | 5/26/17 | AP | T/S: 05/25/2017 11:53 AM LBENNETT ----- |
| | | | T/S: 05/26/2017 03:00 PM DETAYLOR ----- |
| B103 01 | 5/31/17 | DT | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002978187 |
| | 5/31/17 | AP | T/S: 05/30/2017 11:35 AM JBROCK ----- |
| | | | T/S: 05/31/2017 03:33 PM DJOHNSON ----- |
| B105 01 | 6/01/17 | DT | R*OPEN FLOOR TIME: 17:00 VRU #: 002979219 |
| | 6/01/17 | AP | T/S: 05/31/2017 03:33 PM DJOHNSON ----- |
| | | | T/S: 06/01/2017 11:46 AM DETAYLOR ----- |
| R425 01 | 6/08/17 | KS | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002981934 |
| | 6/08/17 | DA | T/S: 06/07/2017 11:28 AM BPETRICH ----- |
| | | | T/S: 06/08/2017 03:28 PM KSLATTUM ----- |
| | | | 1. fire caulking not done. 2. Rat proof tub traps. 3. Washer box at 33 1/2 inches. Minimum is 34. OK to side |
| R425 02 | 6/09/17 | KS | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002982692 |
| | 6/09/17 | AP | T/S: 06/08/2017 02:07 PM LBENNETT ----- |
| | | | T/S: 06/09/2017 03:31 PM KSLATTUM ----- |
| I129 01 | 6/12/17 | DT | R*INSULATION INSPECTION TIME: 17:00 VRU #: 002983294 |
| | 6/12/17 | AP | T/S: 06/09/2017 02:15 PM DJOHNSON ----- |
| | | | T/S: 06/12/2017 02:29 PM DETAYLOR ----- |
| E209 01 | 7/14/17 | DT | R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002997005 |
| | 7/14/17 | AP | T/S: 07/13/2017 09:49 AM DJOHNSON ----- |
| | | | T/S: 07/14/2017 02:37 PM DETAYLOR ----- |
| R429 01 | 7/20/17 | TI | FOUR TRADE FINAL TIME: 17:00 VRU #: 002999860 |
| | 7/20/17 | APDT | T/S: 07/19/2017 08:40 AM LLUCAS ----- |

COMMENTS AND NOTES