HTE# 17-5-41277 Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: US 301 South ISSUED TO: Mindy Parrish SUBDIVISION EXPANSION Site Improvements required prior to Construction Authorization Issuance: 3BR SENS (65' × 66') Type of Structure: ____ Proposed Wastewater System Type: 25% reduction 525. Projected Daily Flow: 360 GPD Number of bedrooms: Number of Occupants: Basement Yes May be required based on final location and elevations of facilities Pump Required: Tes No Type of Water Supply:

Community Public Well Distance from well feet Five years Permit valid for: Permit conditions: ■ No expiration 00/13/2017 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit... Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Mindy Parrish PROPERTY LOCATION: US 301 South SUBDIVISION Facility Type: 3 BR SED (SS' x 66') Wew Expansion Basement Fixtures?

Yes 250 Reduction 5,5 tem (Initial) Wastewater Flow: 360 GPD Type of Wastewater System** (See note below, if applicable

) 75% reduction 525 tem (Repair) Number of trenches 3 Installation Requirements/Conditions Exact length of each trench 100 feet Trench Spacing: 7 Feet on Center Septic Tank Size 1000 gallons Pump Tank Size ____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches (APPROVED Maximum Trench Depth of: 12 inches (Maximum soil cover shall not exceed IMPORT (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Aggregate Depth: _____ inches below pipe inches above pipe _____ inches total Pump Requirements: _____ft. TDH vs. ____ Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Comment Date: 06/13/17 Construction Authorization Expiration Date: 06/13/22

Harnett County Department of Public Health Site Sketch

