

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: WNT LLC

Address: 16 Triden Housing for Pr.

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

50041430

Date: 2/8/19

Building Official: [Signature]

ADDRESS : 16 TILDEN HOWINGTON DR
 CONTRACTOR : WJH LLC
 OWNER : DAKOTA LAND PARTNERS LLC
 PARCEL : 13-0630-01- -0029- -36-
 APPL NUMBER: 17-50041430 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 05/19/2017 09:12 AM JBROCK ----
 421 N LEFT ONTO WILLIE CAMERON RD R
 ONTO OLD 421 L LOT ON TILDEN HOWINGTON
 DR LOT #96

SUBDIV: MAMIE BELL PH# 1&2&5 46LOTS
 PHONE : (336) 282-3606
 PHONE :

STRUCTURE: 000 000 40X50 4BDR MONO W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00
 SEPTIC - EXISTING? : NEW TANK
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	10/30/17	TSG	R*PLUMB UNDER SLAB VRU #: 003046313
	10/30/17	DA	T/S: 10/30/2017 03:29 PM DJOHNSON ----- T/S: 11/01/2017 08:55 AM LLUCAS -----
A814 01	10/30/17	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003046455
	10/30/17	CA	T/S: 10/27/2017 02:43 PM BPETRICH -----
A814 03	11/01/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003047081
	10/31/17	AP	16 TILDEN HOWINGTON DR LILLINGTON 27546 T/S: 10/31/2017 09:54 AM SBENNETT -----
P309 02	11/01/17	TSG	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003047131
	11/01/17	DP	T/S: 10/30/2017 02:08 PM LLUCAS ----- PLEASE SIGN OFF ON PREVIOUS HEAD TEST STILL DOWN
P309 03	11/03/17	TSG	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003048725
	11/03/17	AP	T/S: 11/02/2017 12:51 PM LLUCAS -----
B114 01	11/08/17	TSG	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003050614
	11/08/17	AP	T/S: 11/07/2017 10:51 AM JBROCK -----
R425 01	11/29/17	BP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003058799
	11/29/17	CA	T/S: 11/28/2017 12:02 PM LLUCAS ----- T/S: 11/29/2017 04:10 PM BPETRICH ----- CANCELLED PER CONTRACTOR
B104 01	12/14/17	BP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003067519
	12/14/17	AP	T/S: 12/14/2017 02:07 PM BPETRICH ----- T/S: 12/14/2017 02:07 PM BPETRICH -----
R425 02	12/18/17	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003067527
	12/18/17	DA	T/S: 12/14/2017 02:10 PM BPETRICH ----- T/S: 12/18/2017 12:40 PM KSLATTUM ----- 1. Seal gaps around air barriers beneath knee wall. 2. Knee walls missing air barriers (bonus room. 3. Air barriers needed on attic side in stair well. 5. All trusses bearing on fron porch wall at house require hurricane ties capable of 751 lbs. B2CL need hurricane ties at garage wall Ok to side , do not insulate.
R425 03	12/20/17	TSG	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003069002
	12/20/17	AP	T/S: 12/19/2017 12:20 PM LLUCAS ----- T/S: 12/20/2017 04:16 PM DJOHNSON -----
I129 01	12/22/17	TSG	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003070000
	12/22/17	AP	T/S: 12/21/2017 09:47 AM JBROCK -----

ADDRESS : 16 TILDEN HOWINGTON DR
CONTRACTOR : WJH LLC
OWNER : DAKOTA LAND PARTNERS LLC
PARCEL : 13-0630-01- -0029- -36-
APPL NUMBER: 17-50041430 CP NEW RESIDENTIAL (SFD)

SUBDIV: MAMIE BELL PH# 1&2&5 46LOTS
PHONE : (336) 282-3606
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	1/02/18 1/02/18	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003072865 T/S: 01/03/2018 10:40 AM KHINSON ----- T/S: 01/03/2018 10:40 AM KHINSON -----
M305 01	1/09/18 1/09/18	TSG AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003073459 T/S: 01/05/2018 03:28 PM LLUCAS -----
P307 01	1/09/18 1/09/18	TSG AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003073467 T/S: 01/05/2018 03:28 PM LLUCAS -----
E209 01	1/18/18 1/19/18	TSG AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003077153 T/S: 01/16/2018 02:32 PM LLUCAS ----- T/S: 01/19/2018 04:06 PM LLUCAS -----
R429 01	1/29/18 1/29/18	KS DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 003081023 T/S: 01/25/2018 12:13 PM DJOHNSON ----- T/S: 01/29/2018 12:16 PM KSLATTUM ----- 1. Need energy certificate. 2. Broken top chord on truss to the right of the attic access. Need engineer's repair. Gusset torn away from joint.
R429 02	2/08/18	TT	FOUR TRADE FINAL TIME: 17:00 VRU #: 003086568 T/S: 02/07/2018 11:10 AM LLUCAS ----- ENGINEER LETTER ON COUNTER

COMMENTS AND NOTES