


**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated: 6/23/17  
 Proposed Facility: 4 BODS      Design Flow (.1949):  
 Location of Site:              Property Recorded:  
 Water Supply:               Public  Individual  Well       Spring       Other  
 Evaluation Method:  Auger Boring       Pit       Cut  
 Type of Wastewater:       Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2.5	0-24	G LS	VFI2 NS/HP					
		24-41"	SBK SC	F1 SS/SR					PS 3
2		0-22	G S	VFI2 NS/HP					
		22-28	SBK SC	FR SS/HP					PS .5
3		0-30	G LS	VFI2 NS/HP					
		30-48	SBK SC	FR SS/SP					PS .4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OY Others Present: -
Available Space (.1945)			
System Type(s)	25-8, 260	25-8, 260	
Site LTAR	.3	.3	





**VICINITY MAP**

Not To Scale. PLAN APPROVAL

**SETBACKS**

FRONT - 35'  
 SIDE - 10'  
 REAR - 25'  
 CORNER SIDE - 20'

**NOTE:**

ALL DIMENSIONS, LOCATIONS AND FEATURES SHOWN ON THIS PLOT PLAN ARE APPROXIMATE AND ARE ONLY AN ARTIST'S RENDERING. EXACT LOCATION OF ALL FEATURES ARE SUBJECT TO CHANGE AND MAY NOT BE INSTALLED EXACTLY AS SHOWN ON PLANS AND/OR IN MODELS. PLACEMENT OF HOME, DRIVEWAY, SIDEWALKS AND EXTERIOR FEATURES ARE SUBJECT TO MODIFICATION AS DEEMED NECESSARY BY FIELD PERSONNEL.

CUSTOMER \_\_\_\_\_ DATE \_\_\_\_\_


CUSTOMER \_\_\_\_\_ DATE \_\_\_\_\_

WADE JOURNEY REPRESENTATIVE \_\_\_\_\_ DATE \_\_\_\_\_


**IMPERVIOUS SURFACE AREA**

DESCRIPTION	AREA
HOUSE w/ PORCH	2,078 S.F.
PATIO/HVAC	18 S.F.
DRIVEWAY & WALKS	701 S.F.
<b>TOTAL (PROPOSED)=</b>	<b>2,797 S.F.</b>
<b>LOT AREA =</b>	<b>27,592 S.F.</b>
<b>% IMPERVIOUS AREA</b>	<b>=10.1%</b>

RA30 USE STD  
 BEDROOMS  
 5/19/17 GAB



NCSR # 1291  
 OLD US 421



THIS PROPERTY MAY BE SUBJECT TO ANY AND ALL APPLICABLE DEED RESTRICTIONS, EASEMENTS, RIGHT-OF-WAY, UTILITIES AND RESTRICTIVE COVENANTS WHICH MAY BE OF RECORD OR IMPLIED.

**TILDEN HOWINGTON DRIVE**  
 50' PUBLIC R/W