

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Southern Built, LLC

Address: 3159 Johnston County Rd
Angier, NC 27501

Date: 2-7-18

Building Official: [Signature]

Permit Numbers

Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: 17-50241453
MFG Home: _____

ADDRESS . . : 3159 JOHNSTON COUNTY RD
 CONTRACTOR : SOUTHERN BUILT, LLC
 OWNER . . . : SOUTHERN BUILT LLC
 PARCEL . . . : 07-1603- - -0030- -03-
 APPL NUMBER: 17-50041453 CP NEW RESIDENTIAL (SFD)

SUBDIV:
 PHONE : (910) 214-2227
 PHONE :

STRUCTURE: 000 000 81X46 3BDR W/GARAGE W/DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW SEPTIC
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

65863321

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/22/17	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 003015301
	8/22/17	AP	T/S: 08/22/2017 11:36 AM DETAYLOR -----
B103 01	9/14/17	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 003024435
	9/14/17	AP	T/S: 09/14/2017 10:42 AM DETAYLOR -----
B105 01	10/10/17	DT	R*OPEN FLOOR TIME: 17:00 VRU #: 003044724
	10/10/17	AP	
A814 01	10/26/17	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003044732
	10/25/17	AP	T/S: 10/25/2017 02:19 PM TWARD -----
R425 01	11/20/17	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003055340
	11/20/17	DA	T/S: 11/17/2017 10:45 AM LLUCAS ----- T/S: 11/20/2017 01:51 PM DETAYLOR ----- No test on plumbing drain lines Fire block top of fireplace chase at ceiling
I129 01	11/28/17	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003058237
	11/28/17	AP	T/S: 11/27/2017 01:08 PM JBROCK ----- T/S: 11/28/2017 12:08 PM DETAYLOR -----
R425 02	11/28/17	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003058245
	11/28/17	AP	T/S: 11/27/2017 01:09 PM JBROCK ----- T/S: 11/28/2017 12:08 PM DETAYLOR -----
H824 01	1/24/18	AC	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003081676
	1/24/18	AP	T/S: 01/26/2018 09:52 AM KHINSON ----- T/S: 01/26/2018 09:52 AM KHINSON -----
R429 01	2/07/18 2/7/18	TI AP DT	FOUR TRADE FINAL TIME: 17:00 VRU #: 003085917
			T/S: 02/06/2018 09:19 AM JBROCK -----

COMMENTS AND NOTES