

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: RESIDENTIAL

Name: WYNW CONSTRUCTION

Address: 347 Avery Road Dr

Date: 2/22/18

Building Official: [Signature]

Permit Numbers

Building: 17-SD041490

Electrical: ''

Insulation: ''

Plumbing: ''

Mechanical: ''

MFG Home: _____

ADDRESS : 347 AVERY POND DR SUBDIV: AVERY POND PH2 30LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : LITTLE CROSS LLC PHONE :
 PARCEL : 08-0653- - -0029- -46-
 APPL NUMBER: 17-50041490 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 05/26/2017 11:25 AM JBROCK ----
 AVERY POND #42

STRUCTURE: 000 000 60X60 4BDR CRAWL W/ GARAGE & COV B PORCH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	10/20/17 10/20/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003042025 347 AVERY POND DR FUQUAY VARINA 27526 T/S: 10/20/2017 09:51 AM SBENNETT -----
B101 01	10/20/17 10/20/17	BS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 003042017 T/S: 10/19/2017 01:37 PM BPETRICH ----- T/S: October 20, 2017 11:17 AM BSUTTON -----
B103 01	11/01/17 11/01/17	KS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003047685 T/S: 10/31/2017 01:28 PM BPETRICH ----- T/S: 11/01/2017 03:04 PM KSLATTUM -----
B105 01	11/08/17 11/08/17	BS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 003050762 T/S: 11/07/2017 11:50 AM JBROCK ----- T/S: November 08, 2017 11:05 AM BSUTTON -----
B104 01	12/07/17 12/07/17	BP AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003063914 T/S: 12/07/2017 01:21 PM BPETRICH ----- T/S: 12/07/2017 01:21 PM BPETRICH -----
R425 01	12/08/17 12/08/17	MC DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003063922 T/S: 12/07/2017 01:26 PM BPETRICH ----- T/S: 12/08/2017 04:01 PM MCOOK ----- 1. MISSING WINDOW BACK MASTER BEDROOM 2. MISSING UPLIFT ON TRUSS AV1,AV2 3. MISSING BRACE TRUSS CO1 4. MISSING UPLIFT ON ALL GABLE TRUSS 5. MISSING NAILM PLATE HALL BATH UPSTAIRS 6. MISSING F/D STOP AT CHASE BEHIND HALL BATH 7. WIRING NEEDS REWIRING AT MASTER BEDROOM 8. BOND ALL BATH FANS 9. STRAP WALLS AT STAIRS , UPSTAIRS BEDROOM RIGHT BACK AT CORNER , AND AT GARAGE 10. F/D STOP ALL GARAGE 11. TAPE FLASHING AT FRONT PORCH AND INSTALL FLASHING BEHIND ROWLOCKS
R425 02	12/13/17 12/13/17	MC DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003066065 T/S: 12/12/2017 12:26 PM LLUCAS ----- T/S: 12/13/2017 10:40 AM MCOOK ----- 1. MISSING NAIL GAURD #5 2. MISSING STRAP BACK UP BEDROOM OK TO INSULATE
I129 01	12/15/17 12/15/17	MC AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003067345 T/S: 12/14/2017 01:08 PM BPETRICH ----- T/S: 12/15/2017 03:19 PM MCOOK -----
R425 03	12/15/17 12/15/17	MC AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003067337 T/S: 12/14/2017 01:08 PM BPETRICH ----- T/S: 12/15/2017 03:19 PM MCOOK -----
R125 01	1/12/18	MC	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003075652

ADDRESS : 347 AVERY POND DR SUBDIV: AVERY POND PH2 30LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : LITTLE CROSS LLC PHONE :
 PARCEL : 08-0653- - -0029- -46-
 APPL NUMBER: 17-50041490 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	1/12/18	AP	T/S: 01/11/2018 01:19 PM BPETRICH STONE PREP
E209 01	1/31/18	MC	T/S: 01/12/2018 04:41 PM MCOOK R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003082823
	1/31/18	AP	T/S: 01/30/2018 11:20 AM BPETRICH T/S: 01/31/2018 02:23 PM MCOOK CALLED IN
H824 01	2/01/18	AC	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003085347
	2/01/18	AP	T/S: 02/05/2018 10:29 AM KHINSON T/S: 02/05/2018 10:29 AM KHINSON
M305 01	2/02/18	MC	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003084464
	2/02/18	AP	T/S: 02/01/2018 11:46 AM LLUCAS T/S: 02/02/2018 02:53 PM MCOOK
R429 01	2/22/18	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 003092830
	<u>✓</u>	<u>AP</u>	T/S: 02/21/2018 01:11 PM BPETRICH

COMMENTS AND NOTES