

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: RESIDENTIAL

Name: WYNN CONSTRUCTION

Address: 448 AVERYFORD DR.

Date: 1/9/18

Building Official: Mike Cook

Permit Numbers

Building: 17-50041496

Electrical: ''

Insulation: ''

Plumbing: ''

Mechanical: ''

MFG Home: _____

ADDRESS : 448 AVERY POND DR SUBDIV: AVERY POND PH2 30LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : LITTLE CROSS LLC PHONE :
 PARCEL : 08-0653- - -0029- -57-
 APPL NUMBER: 17-50041496 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 05/26/2017 11:25 AM JBROCK ----
 AVERY POND #53
 T/S: 09/12/2017 09:48 AM JBROCK ----
 Premise# 30644887

STRUCTURE: 000 000 60X60 4BDR CRAWL W/ GARAGE & COV B PORCH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| B101 01 | 9/14/17 | JLP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 003024391 |
| | 9/14/17 | AP | T/S: 09/14/2017 03:07 PM JPERRY ----- |
| A814 01 | 9/19/17 | SB | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003026721 |
| | 9/19/17 | AP | 448 AVERY POND DR FUQUAY VARINA 27526 T/S: 09/19/2017 09:38 AM SBENNETT ----- |
| B103 01 | 9/19/17 | JLP | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003026739 |
| | 9/19/17 | AP | T/S: 09/18/2017 01:39 PM JBROCK ----- T/S: 09/19/2017 03:13 PM JPERRY ----- |
| B105 01 | 9/28/17 | DT | R*OPEN FLOOR TIME: 17:00 VRU #: 003031127 |
| | 9/28/17 | AP | T/S: 09/27/2017 01:27 PM BPETRICH ----- T/S: 09/28/2017 12:07 PM DETAYLOR ----- |
| B104 01 | 10/26/17 | BP | R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003045747 |
| | 10/26/17 | AP | T/S: 10/26/2017 03:16 PM BPETRICH ----- T/S: 10/26/2017 03:17 PM BPETRICH ----- |
| R425 01 | 10/26/17 | BS | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003044435 |
| | 10/26/17 | DA | T/S: 10/25/2017 11:39 AM BPETRICH ----- T/S: October 26, 2017 12:35 PM BSUTTON ----- Install missing stud at front closet. 2. Need truss repair letter for floor trusses at stairway. OK to side/insuate |
| I129 01 | 11/01/17 | KS | R*INSULATION INSPECTION TIME: 17:00 VRU #: 003047560 |
| | 11/01/17 | AP | T/S: 10/31/2017 11:56 AM BPETRICH ----- T/S: 11/01/2017 03:04 PM KSLATTUM ----- |
| R425 02 | 11/01/17 | KS | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003047552 |
| | 11/01/17 | AP | T/S: 10/31/2017 11:56 AM BPETRICH ----- T/S: 11/01/2017 03:04 PM KSLATTUM ----- |
| H824 01 | 11/29/17 | AC | ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003059995 |
| | 11/29/17 | AP | T/S: 11/30/2017 10:50 AM KHINSON ----- T/S: 11/30/2017 10:50 AM KHINSON ----- |
| R125 01 | 12/04/17 | BS | ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003060894 |
| | 12/04/17 | CA | T/S: 12/01/2017 11:33 AM BPETRICH ----- STONE PREP T/S: December 04, 2017 09:23 AM BSUTTON ----- per oliver |
| M305 01 | 12/06/17 | BS | R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003062643 |
| | 12/06/17 | AP | T/S: 12/05/2017 01:37 PM BPETRICH ----- T/S: December 06, 2017 12:55 PM BSUTTON ----- |
| R125 02 | 12/06/17 | BS | ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003062635 |

ADDRESS . : 448 AVERY POND DR
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER . . : LITTLE CROSS LLC
 PARCEL . . : 08-0653- - -0029- -57-
 APPL NUMBER: 17-50041496 CP NEW RESIDENTIAL (SFD)

SUBDIV: AVERY POND PH2 30LTS
 PHONE : (919) 528-1347
 PHONE :

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| | 12/06/17 | AP | T/S: 12/05/2017 01:37 PM BPETRICH ----- STONE PREP |
| E209 01 | 12/08/17 | MC | T/S: December 06, 2017 12:55 PM BSUTTON ----- R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003063930 |
| | 12/08/17 | AP | T/S: 12/07/2017 01:26 PM BPETRICH ----- T/S: 12/08/2017 04:00 PM MCOOK ----- |
| R429 01 | 1/04/18 | MC | FOUR TRADE FINAL TIME: 17:00 VRU #: 003073004 |
| | 1/05/18 | DA | T/S: 01/03/2018 12:58 PM JBROCK ----- T/S: 01/05/2018 03:28 PM MCOOK ----- 1. INSULATE ATTIC SCUTTLE DOOR AND AROUND JAMB 2. INSTALL BRACE ON DECK |
| R429 02 | 1/09/18 | TI | FOUR TRADE FINAL TIME: 17:00 VRU #: 003073319 |
| | <u>11</u> | | T/S: 01/05/2018 01:08 PM BPETRICH ----- |

COMMENTS AND NOTES