

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: RESIDENTIAL

Name: WYNN CONSTRUCTION

Address: 434 AVERY POND RD.

Date: 1/9/18

Building Official: M. L. COOK

Permit Numbers

Building: 17-50041497

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____

ADDRESS : 434 AVERY POND DR SUBDIV: AVERY POND PH2 30LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : LITTLE CROSS LLC PHONE :
 PARCEL : 08-0653- - -0029- -58-
 APPL NUMBER: 17-50041497 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 05/26/2017 11:25 AM JBROCK ----
 AVERY POND #54
 T/S: 09/12/2017 09:48 AM JBROCK ----
 Premise# 02931965
 T/S: 12/06/2017 12:10 PM DJOHNSON --
 ***PER EH CUSTOMER CANNOT ADD A POOL TO
 THIS SITE WITHOUT HIRING A PRIVATE SOIL
 SCIENTIST*****

STRUCTURE: 000 000 60X60 4BDR CRAWL W/ GARAGE & COV B PORCH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/14/17	JLP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 003024417
	9/14/17	AP	T/S: 09/14/2017 03:07 PM JPERRY -----
A814 01	9/26/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003030194
	9/26/17	AP	434 AVERY POND DR FUQUAY VARINA 27526 T/S: 09/26/2017 09:14 AM SBENNETT -----
B103 01	9/26/17	TSG	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003030202
	9/26/17	AP	T/S: 09/25/2017 02:05 PM JBROCK -----
B105 01	10/06/17	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 003034568
	10/06/17	AP	T/S: 10/04/2017 02:01 PM BPETRICH ----- T/S: October 06, 2017 02:27 PM BSUTTON -----
B104 01	10/26/17	BP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003045770
	10/26/17	AP	T/S: 10/26/2017 03:17 PM BPETRICH ----- T/S: 10/26/2017 03:17 PM BPETRICH -----
R425 01	10/31/17	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003046877
	10/31/17	DA	T/S: 10/30/2017 12:01 PM LLUCAS ----- T/S: 10/31/2017 10:57 AM KSLATTUM ----- 1. H1 trussweb broken and gusset over laundry separated from truss, 2, insufficient uplift on gdr,hgr and hgr1, 3, no pressure on gas line ok oside and insulate
I129 01	11/03/17	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003048758
	11/03/17	AP	T/S: 11/02/2017 12:59 PM BPETRICH ----- T/S: November 03, 2017 12:36 PM BSUTTON -----
R425 02	11/03/17	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003048766
	11/03/17	AP	T/S: 11/02/2017 12:59 PM BPETRICH ----- T/S: November 03, 2017 12:36 PM BSUTTON -----
R125 01	12/04/17	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003060902
	12/04/17	CA	T/S: 12/01/2017 11:34 AM BPETRICH ----- STONE PREP T/S: December 04, 2017 09:23 AM BSUTTON ----- per oliver
R125 02	12/06/17	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003062650
	12/06/17	AP	T/S: 12/05/2017 01:37 PM BPETRICH ----- STONE PREP

ADDRESS : 434 AVERY POND DR
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : LITTLE CROSS LLC
PARCEL : 08-0653- - -0029- -58-
APPL NUMBER: 17-50041497 CP NEW RESIDENTIAL (SFD)

SUBDIV: AVERY POND PH2 30LTS
PHONE : (919) 528-1347
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E209 01	12/20/17 12/20/17	DT AP	T/S: December 06, 2017 12:55 PM BSUTTON ----- R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003069044 T/S: 12/19/2017 12:34 PM DJOHNSON ----- T/S: 12/20/2017 04:30 PM DETAYLOR -----
H824 01	12/28/17 12/29/17	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003072089 T/S: 12/29/2017 11:02 AM SSTEWARD ----- T/S: 12/29/2017 11:03 AM SSTEWARD -----
M305 01	12/29/17 12/29/17	MC AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003071487 T/S: 12/28/2017 10:35 AM BPETRICH ----- T/S: 12/29/2017 02:47 PM MCOOK -----
R429 01	1/09/18 <u>11</u>	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 003073327 T/S: 01/05/2018 01:08 PM BPETRICH -----

----- COMMENTS AND NOTES -----