

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Precision Custom Homes
PROPERTY LOCATION: 31 Summerlin Dr
SUBDIVISION: Summerlin LOT # 32
Type of Structure: SFD (40x40)
Proposed Wastewater System Type: 25% Reduction System
Projected Daily Flow: 480 GPD
Number of bedrooms: 4 Number of Occupants: 8 max
Basement: No
Pump Required: No
Type of Water Supply: Public
Permit valid for: Five years

Authorized State Agent: [Signature] Date: 6/13/17
SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: Precision Custom Homes
PROPERTY LOCATION: 31 Summerlin Dr
SUBDIVISION: Summerlin LOT # 32
Facility Type: SFD (40x40) New
Basement? No
Type of Wastewater System: 25% Reduction System
(Initial) Wastewater Flow: 480 GPD

Installation Requirements/Conditions
Septic Tank Size: 1000 gallons
Pump Tank Size: [blank] gallons
Number of trenches: 2
Exact length of each trench: 100 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 6-12 inches
Maximum Trench Depth: 18-24 inches
Pump Requirements: [blank] ft. TDH vs. [blank] GPM
Aggregate Depth: [blank] inches above pipe, [blank] inches below pipe, [blank] inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: [Signature] Date: [blank]

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes.
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
Authorized State Agent: [Signature] Date: 6/13/17
Construction Authorization Expiration Date: 6/23/22

HTE# 17-5-41559

Permit # 29544

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Precision Custom Homes PROPERTY LOCATOR: 31 Summerlin Dr  
SUBDIVISION Summerlin LOT # 32

Authorized State Agent: ~~AGHS (OLIVER TOLKSON)~~ Date: 6/13/17

