

ADDRESS : 564 SPRING FLOWERS DR SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
 OWNER : CUMBERLAND HOMES INC PHONE :
 PARCEL : 09-9567-02- -0006- -33-
 APPL NUMBER: 17-50041578 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/07/2017 04:48 PM BPETRICH --
 CAROLINA SEASONS #34
 TAKE HWY 27W TO JOHNSONVILLE SCHOOL
 ROAD - RIGHT TO PONDEROSA ROAD - RIGHT
 INTO CAROLINA SEASONS

STRUCTURE: 000 000 37X49 4BD3BA SLAB W/FINBON W/GAR W/PATIO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	8/24/17 8/24/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003016706 564 SPRING FLOWERS DR CAMERON 28326 T/S: 08/24/2017 09:40 AM SBENNETT -----
B101 01	8/24/17 8/24/17	JLP AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 003016722 T/S: 08/23/2017 01:48 PM BPETRICH ----- T/S: 08/24/2017 01:55 PM JPERRY -----
B103 01	9/08/17 9/08/17	TSG DA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003022316 T/S: 09/07/2017 09:41 AM BPETRICH ----- 1- INSTALL ANCHOR BOLTS MIN 7" EMBEDMENT IN CONCRETE OR MASONARY 2-CUT INSULATION DOWN TO BOTTOM OF SLAB 3-ATTACH INSULATION IN AREEAS IT HAS FALLEN DOWN 4-DO NOT HOLD INSULATION UP WITH DIRT
B103 02	9/15/17 9/15/17	TSG AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003024494 T/S: 09/13/2017 02:33 PM JBROCK -----
B111 01	9/26/17 9/26/17	JH DP	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 003029899 NOT READY FOR SLAB INSPECTION -----
E205 01	9/26/17 9/25/17	TI CA	R*ELEC UNDER SLAB VRU #: 003029873
P309 01	9/28/17 9/28/17	TSG AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003031291
B111 02	9/29/17 9/29/17	TSG AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 003031879 T/S: 09/28/2017 01:57 PM BPETRICH ----- T/S: 09/29/2017 02:56 PM SGUY -----
R425 01	11/27/17 11/27/17	TSG DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003057361 T/S: 11/22/2017 09:00 AM BPETRICH ----- 1- rear entry door not installed 2-strap garage entru door lvl 3-nail back side of triple lvl in garage 4- head test down.
R425 02	11/29/17 11/29/17	TSG AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003058856 T/S: 11/28/2017 12:51 PM DJOHNSON -----
I129 01	12/04/17 12/04/17	TSG AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003061306 T/S: 12/01/2017 02:54 PM LLUCAS -----
R125 01	12/07/17 12/07/17	TSG AP	ONE TRADE ROUGH IN VRU #: 003063393 Stone Prep Inspection T/S: 12/07/2017 03:33 PM LLUCAS -----
H824 01	2/07/18	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003087244

PREPARED 5/30/18, 13:57:55
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 1
DATE 5/31/18

ADDRESS : 564 SPRING FLOWERS DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : CUMBERLAND HOMES INC
PARCEL : 09-9567-02- -0006- -33-
APPL NUMBER: 17-50041578 CP NEW RESIDENTIAL (SFD)

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
PHONE : (910) 892-4345
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	2/07/18	AP	T/S: 02/08/2018 09:58 AM KHINSON
			T/S: 02/08/2018 09:58 AM KHINSON
E209 01	4/17/18	TSG	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003115201
	4/17/18	AP	T/S: 04/16/2018 01:13 PM JBROCK
			T/S: 04/17/2018 03:34 PM tsg
R429 01	5/31/18	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 003133519
			T/S: 05/30/2018 10:09 AM BPETRICH

COMMENTS AND NOTES