Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address:
Proposed Facility: 4 BDRM
Location of Site:
Water Supply: ☐ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☐ Sewage ☐ Industrial Process ☐ Mixed

Date Evaluated: 6/21/17
Design Flow (.1949): 480 gpd
Property Recorded:
Property Size:

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-48	G S	VFR NS/NP					S8
2		0-48		VFR NS/NP					S8

Description	Initial System	Repair System
Available Space (.1945)		✓
System Type(s)	[illegible]	25% [illegible]
Site LTAR	4	.4

Other Factors (.1946):
Site Classification (.1948): S
Evaluated By: [illegible]
Others Present:

SEE PROPOSAL