

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 6/30/17
 Proposed Facility: 4302M Design Flow (.1949): 480 gal/d
 Location of Site: Property Recorded: Property Size:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-22	G SL	VFA NS/NP					
		22-40	SBK SCL	FN S/SP					PS .4
2		0-24	G SCL	VFA NS/NP					
		24-48	G SL	VFA NS/NP					S .1
3		0-22	G SL	VFA NS/NP					
		22-40	SBK SCL	FN S/SP					PS .4
4		0-24	G SL	VFA NS/NP					
		24"	SBK SCL	FN S/SP					PS .4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: -
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	25' x 20' ED.		
Site LTAR	.4	H	