

July 13, 2017

Matthew Turner  
1120 Carson Gregory Rd  
Angier, NC 27501

**RE: Existing Septic System Inspection HTE# 17-5-41774**

Dear Mr. Turner,

An attempt was made to evaluate your property for the purpose of issuing an Existing Tank Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncovered outlet lid on septic tank and break seal. (*\$25.00 fee incurred*)
- 2. Have system pumped out
- 3. Replace sanitary T
- 4. Other – **Parts of lines crushed.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James Manhart, III, R.E.H.S.  
Environmental Health OSWW Program Specialist  
Harnett County Department of Public Health  
Environmental Health

JM/kh  
Copy - Central Permitting